

Air System Sizing Summary for Packaged Rooftop AHU

Project Name: Example Problem
Prepared by: Carrier Corporation

08/27/2002
03:22PM

Air System Information

Air System Name **Packaged Rooftop AHU**
Equipment Class **PKG ROOF**
Air System Type **VAV**

Number of zones **11**
Floor Area **9700.0 ft²**

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Peak zone sensible load**
Space CFM **Individual peak space loads**

Calculation Months **May to Nov**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **32.1** Tons
Total coil load **384.9** MBH
Sensible coil load **275.2** MBH
Coil CFM at Aug 1600 **7815** CFM
Max block CFM at Aug 1700 **8445** CFM
Sum of peak zone CFM **8586** CFM
Sensible heat ratio **0.715**
ft²/Ton **302.4**
BTU/(hr-ft²) **39.7**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Aug 1600**
OA DB / WB **91.0 / 74.0 °F**
Entering DB / WB **86.5 / 68.9 °F**
Leaving DB / WB **53.1 / 52.4 °F**
Coil ADP **51.4 °F**
Bypass Factor **0.050**
Resulting RH **47 %**
Design supply temp. **55.0 °F**
Zone T-stat Check **11 of 11 OK**
Max zone temperature deviation **0.0 °F**

Preheat Coil Sizing Data

Max coil load **191.7** MBH
Coil CFM at Des Htg **3136** CFM
Max coil CFM **8445** CFM
Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
Ent. DB / Lvg DB **-6.0 / 52.0 °F**

Supply Fan Sizing Data

Actual max CFM at Aug 1700 **8445** CFM
Standard CFM **8242** CFM
Actual max CFM/ft² **0.87** CFM/ft²

Fan motor BHP **7.38** BHP
Fan motor kW **5.50** kW
Fan static **3.00** in wg

Outdoor Ventilation Air Data

Design airflow CFM **3142** CFM
CFM/ft² **0.32** CFM/ft²

CFM/person **15.55** CFM/person