

## Installation Instructions

Part No: 00EFN900008300A

### SAFETY CONSIDERATIONS

Installation of this accessory can be hazardous due to system pressures, electrical components, and equipment locations (such as a roof or elevated structure).

Only trained, qualified installers and service technicians should install, start up, and service this equipment.

When installing this accessory, observe precautions in the literature and on any labels attached to the equipment, and all other safety precautions that may apply.

- Follow all safety codes.
- Wear safety glasses and work gloves.
- Use care in handling and installing this accessory.

#### **WARNING**

Electrical shock can cause personal injury and death. Shut off all power to this equipment during installation. There may be more than one disconnect switch. Tag all disconnect locations to alert others not to restore power until work is completed.

### INTRODUCTION

This accessory package is intended for use with the 30RB060-390 Series F units. See Table 1 for accessory package usage.

**Table 1 — Accessory Package Usage**


| UNIT              | SIZE        | QUANTITY |
|-------------------|-------------|----------|
| 30RB,<br>SERIES F | 060,070     | 3        |
|                   | 080,090,100 | 4        |
|                   | 110,120     | 5        |
|                   | 130,150     | 6        |
|                   | 160,170     | 7        |
|                   | 190         | 8        |
|                   | 210,225     | 9        |
|                   | 250         | 10       |
|                   | 275         | 11       |
|                   | 300         | 12       |
|                   | 315,330,345 | 14       |
|                   | 360         | 15       |
|                   | 390         | 16       |

NOTE: This blanket accessory is not compatible with Danfoss SH300 compressors.


### INSTALLATION

The following are the procedures to install the low sound compressor blanket on 30RB units. The sound blanket kit includes blanket and blanket cap.

1. Align the suction and discharge line slots on the blanket to the tubes. See Fig. 1.
2. Wrap the sound blanket around the compressor in a clockwise direction.
3. Align the oil equalizer line slots in the blanket to the tube at the back of the compressor. See Fig. 1.
4. Finish wrapping the compressor by joining the hook and loop strips near the suction and discharge lines.
5. Clean the compressor electrical box on both sides.
6. Separate the hook strip from the blanket, peel the protective cover off the back of the strip, and stick the strip to the clean compressor electrical box. Repeat on the other side. See Fig. 2. Attach blanket to strip.
7. Install the blanket cap by aligning the slot in the blanket cap to the discharge line. Align the three hook strips on the cap to the loop strips on the blanket.
8. Repeat from Step 1 for other compressors.



**Fig. 1 — Wrap Sound Blanket**



**Fig. 2 — Complete Wrapping**