

PSC Inducer Motor Housing Assembly Kit

Cancels: IIK 340M-40-64 IIK 340M-40-81
8-05

Installation Instructions Part No. 320725-753

NOTE: Read the entire instruction manual before starting the installation.

This symbol → indicates a change since the last issue.

SAFETY CONSIDERATIONS

Installing and servicing of heating equipment can be hazardous due to gas and electrical components. Only trained personnel should install or service heating equipment.

Untrained personnel can perform basic maintenance functions such as cleaning coils or cleaning and replacing filters. All other operations should be performed by trained service personnel. When working on heating equipment, observe precautions in the literature, on tags, and on labels attached to the unit.

Follow all safety codes. Wear safety glasses and work gloves. Have fire extinguisher available.

Recognize safety information. This is the safety-alert symbol . When you see this symbol on the furnace and in instructions or manuals, be alert to the potential for personal injury.

Understand the signal words DANGER, WARNING, and CAUTION. These words are used with the safety-alert symbol. DANGER identifies the most serious hazards which **will** result in severe personal injury or death. WARNING signifies a hazard which **could** result in personal injury or death. CAUTION is used to identify unsafe practices which **may** result in minor personal injury or product and property damage. NOTE is used to highlight suggestions which **will** result in enhanced installation, reliability, or operation.

WARNING

FIRE, EXPLOSION AND ELECTRICAL SHOCK HAZARD

Failure to follow this warning could result in personal injury, death and/or property damage.

Before beginning any installation or modification, be sure the main electrical disconnect switch is in the OFF position.

CAUTION

UNIT DAMAGE HAZARD

Failure to follow this caution may result in improper and dangerous operation.

Label all wires prior to disconnection when servicing controls to prevent miswiring.

INTRODUCTION

→ This instruction covers installation of the permanent split capacitor (PSC) inducer motor kit Part No. 320725-753 on models 340MAV, 340AAV, 345MAV, 350MAV, 350AAV, 351DAS, 490AAV, 58MCA, 58MCB, 58MSA, 58MXA, 58MXB, PG9MAA, and PG9MAB Condensing Gas Furnaces. See Table 1 for kit applicability.

→ Table 1—Kit Usage

MODEL NUMBER	SERIES	USED ON
351DAS	A	All Sizes
340MAV 350MAV 490AAV	A, B, C	All Sizes
340MAV 350MAV 490AAV	D and Later Series	All Sizes Except 060120 and 060140*
345MAV	A and Later Series	All Sizes Except 060120*
58MCA 58MXA	100, 110, 120	All Sizes
58MCA 58MXA	130 and Later Series	All Sizes Except 120-20 and 140-20*
58MSA	100 and Later Series	All Sizes Except 120-20*
PG9MAA	A and Later Series	All Sizes Except 060120 and 060140*
340AAV 350AAV	A and Later Series	All Sizes Except 060120 and 060140*
58MCB 58MXB	100 and Later Series	All Sizes Except 120-20 and 140-20*
PG9MAB	A and Later Series	All Sizes Except 060120 and 060140*

* For 060120 and 120-20 size units on models and series specified, use high output PSC inducer motor housing assembly kit, Part No. 320725-754. For 060140 and 140-20 size units on models and series specified, use high output PSC inducer motor housing assembly kit, Part No. 320725-755.

DESCRIPTION AND USAGE

Use this PSC inducer motor kit to replace a failed inducer motor assembly.

This kit contains the following items:


Inducer assembly	1
Installation Instructions	1

NOTE: Inducer assembly consists of motor and fan, capacitor, wheel, motor mount, inducer cover, inducer housing, vent cap, and vent clamp.

INSTALLATION

Step 1—Remove Old Motor Assembly

1. Turn off gas and electrical supplies to unit.
2. Remove main furnace door.
3. Remove drain tube from inducer motor mounting cover plate.
4. Remove pressure switch tubes. (See Fig. 1.)
 - a. Remove tube attached to pressure switch from collector box.
 - b. Remove tube attached to pressure switch from burner enclosure and gas valve.



NOTE: Actual component location may vary depending on model and series.

Fig. 1—Inducer Motor Assembly in Upflow Furnace Orientation

5. Remove screw securing pressure switch and capacitor to inducer housing.
6. Disconnect motor lead connector at quick-connect.
7. Disconnect vent pipe from inducer housing by loosening coupling clamp on inducer outlet. If coupling has 2 clamps, loosen clamp on vent pipe side. Move pipe out of furnace casing.
8. Using backup wrench, disconnect gas supply pipe from gas valve.
9. Remove wires from gas valve. Note location for reassembly.
10. Remove burner enclosure cover.
11. Remove screws securing manifold to burner enclosure.
12. Remove manifold, orifices, and gas valve as 1 assembly.
13. Remove 4 bolts attaching inducer housing assembly to heat exchanger cell panel.

Step 2—Install New Motor Assembly

1. Inspect seal on collector box. (See Fig. 2.)

→ **NOTE:** If collector box seal is damaged in any way, it must be repaired. To repair, apply sealant releasing agent such as PAM cooking spray or equivalent (must not contain corn or canola oil, halogenated hydrocarbons or aromatic content to prevent inadequate sealing) to inducer housing. Apply a small bead of G.E. RTV 162, G.E. 6702, or Dow-Corning RTV 738 sealant to groove in collector box. G.E. 162 (P771-9003) is available through RCD in 3-oz. tubes.

2. Remove 4 bolts and spacers from old inducer housing assembly.
3. Install spacers in new inducer housing.
4. Insert bolts through inducer housing.

NOTE: Inserting bolts at this time will add to the ease of their installation later.

5. Install new inducer housing assembly to heat exchanger cell panel by aligning guide pins in collector box.




Fig. 2—Inducer Housing to Collector Box Gasket

NOTE: Do not pinch collector box pressure tube when assembling inducer housing to collector box.

6. Tighten 4 bolts securing inducer housing assembly to heat exchanger cell panel.
7. Remove screw securing capacitor and reuse to secure pressure switch and capacitor to inducer motor mounting cover plate.
8. Reconnect pressure switch tubes. See tubing label on furnace for proper connections.
 - a. Connect tube from burner enclosure and gas valve to pressure switch.
 - b. Connect tube from collector box to pressure switch.
9. Reconnect motor leads to quick-connect.
10. Reconnect drain tube to inducer motor mounting cover plate.
11. Remove cap and clamp from unused drain connection on old inducer motor mounting cover plate and install on new inducer motor mounting cover plate.
- 12. Connect vent pipe by inserting pipe through elastomeric (rubber) coupling and fully into inducer housing outlet. Tighten coupling clamp screw(s) to 15 in.-lb of torque.

⚠ WARNING

FIRE AND EXPLOSION HAZARD

Failure to follow this warning could result in personal injury, death and/or property damage.

After completing installation, vent pipe must be installed and fully seated against inducer housing internal stop. Coupling clamp screw(s) must be tightened to 15 in.-lb of torque to prevent disassembly of vent from furnace, and to prevent vent gas and condensate leakage.

13. Reinstall manifold assembly with gas valve to burner box. Replace mounting screws.
14. Replace burner box cover.
15. Using backup wrench, reconnect gas supply pipe to gas valve to prevent rotation and improper orientation.

NOTE: Use propane gas resistant pipe dope to prevent gas leaks. DO NOT use Teflon tape.

⚠ WARNING

FIRE AND EXPLOSION HAZARD

Failure to follow this warning could result in personal injury, death and/or property damage.

Gas valve switch or knob **MUST** be facing forward or tilted upward.

16. Reconnect wires to gas valve. Refer to furnace wiring diagram for proper wire location.
17. Turn on gas and electrical supplies to unit.
18. Check for gas leaks.

⚠ WARNING

FIRE AND EXPLOSION HAZARD

Failure to follow this warning could result in personal injury, death and/or property damage.

Never use matches, candles, flame, or other sources of ignition to check for gas leakage. Use a soap-and-water solution.

19. Check furnace operation through 2 complete cycles.
20. Reinstall main furnace door.

