


C5A8T, H5A8T, T5A8T SPLIT-SYSTEM AIR CONDITIONERS WITH R-454B REFRIGERANT 2 To 5 Tons

Wiring Diagram



Total System Charge (lbs.)	Minimum Floor Area (sq.ft.)
4	61
5	76
6	91
7	106
8	122
9	137
10	152
11	167
12	182
13	198
14	213
15	228
16	243
17	259
18	274
19	289
20	304
21	319
22	335
23	350
24	365
25	380

Total Refrigerant Charge (lbs)

Initial _____

+ Added _____

= Total _____

Fig. 1 – Size 2 through 5 Tons

