345488-751 Door Latch Repair Kit

Installation Instructions

NOTE: Read the entire instruction manual before starting the installation.

SAFETY CONSIDERATIONS

Improper installation, adjustment, alteration, service, maintenance, or use can cause explosion, fire, electrical shock or other conditions which may cause death, personal injury or property damage. Consult a qualified installer, service agency, or your distributor or branch for information or assistance. The qualified installer or agency must use factory-authorized kits or accessories when modifying this product. Refer to the individual instructions packaged with the kits or accessories when installing.

Follow all safety codes. Wear safety glasses, protective clothing and work gloves. Use quenching cloths for brazing operations. Have fire extinguisher available. Read these instructions thoroughly and follow all warnings or cautions attached to the unit. Consult local building codes and the current editions of the National Electrical Codes (NEC) NFPA 70.

In Canada, refer to the current editions of the Canadian Electrical Code CSA C22.1.

Recognize safety information. This is the safety-alert symbol \wedge . When you see this symbol on the unit and in instructions or manuals, be alert to the potential for personal injury.

Understand the signal words DANGER, WARNING and CAUTION. These words are used with the safety-alert symbol. DANGER identifies the most serious hazards which will result in severe personal injury or death. WARNING signifies hazards which could result in personal injury or death. CAUTION is used to identify unsafe practices, which may result in minor personal injury or product and property damage. NOTE is used to highlight suggestions which will result in enhanced installation, reliability, or operation.

. WARNING

ELECTRICAL SHOCK HAZARD

Failure to follow this warning could result in personal injury or death. Before installing, modifying or servicing system, always turn off main power to system. There may be more than one disconnect switch. Lock out and tag switch with a suitable warning label.

A CAUTION

CUT HAZARD

Failure to follow this caution may result in personal injury.

Sheet metal parts may have sharp edges or burrs. Use care and wear appropriate protective clothing and gloves when handling parts.

INTRODUCTION

This Door Latch Repair Kit is for all sizes and versions of the DGAPA and PGAPA Air Purifiers.

KIT CONTENTS



INSTALLATION

Make sure to turn off and lock out all power sources to the unit. Read these complete instructions before starting to make sure you understand the steps.

1. Turn off power to the unit.



2. Remove the door from the unit.




3. Remove the filter.



4. Remove the FEM (Filter Enhancement Module).




5. Use a 1/8-inch drill bit to drill out the door latch rivets.



6. Replace the door latch, and insert the supplied screws in the existing holes.



7. Install the supplied nuts to the back of the screws and tighten with a Phillips head screw driver and hex key.





Catalog No: IIK-1110011-01

©2021 Carrier Corp.

7310 W. Morris Street • Indianapolis, IN 46231

Edition Date: 06/21 Replaces: New