

Cooling Capacities
38HDV009 with 40QNC009

Temp (F) Air Entering Condenser (Edb)		Air Entering Evaporator - Cfm/BF											
		135/0.04				170/0.04				230/0.05			
		Air Entering Evaporator - Ewb (F)											
		57	62	67	72	57	62	67	72	57	62	67	72
55	TCG	7.8	8.9	9.6	10.3	8.6	9.4	10.1	10.7	9.3	9.9	10.5	11.0
	SHG	6.6	6.4	5.8	5.0	7.6	7.1	6.3	5.3	8.9	7.8	6.7	5.7
	TC	7.7	8.8	9.5	10.1	8.5	9.3	9.9	10.6	9.2	9.8	10.4	10.9
	kW	0.63	0.64	0.64	0.65	0.64	0.64	0.65	0.66	0.64	0.65	0.66	0.67
	CMP	0.53	0.54	0.55	0.56	0.54	0.54	0.55	0.57	0.54	0.55	0.56	0.58
	LDB	36.0	38.1	42.0	47.8	40.0	43.0	47.6	52.9	45.2	49.7	54.3	58.6
	LWB	31.9	35.6	41.5	47.8	35.7	40.8	46.7	52.9	40.6	46.2	52.1	58.1
65	TCG	7.3	8.6	9.5	10.2	8.2	9.2	10.0	10.7	9.0	9.8	10.5	11.1
	SHG	6.3	6.1	5.7	5.0	7.2	6.9	6.2	5.3	8.7	7.8	6.8	5.7
	TC	7.2	8.4	9.3	10.1	8.0	9.1	9.8	10.5	8.9	9.7	10.4	11.0
	kW	0.70	0.71	0.72	0.73	0.71	0.72	0.73	0.74	0.72	0.72	0.74	0.75
	CMP	0.60	0.62	0.62	0.63	0.61	0.62	0.63	0.64	0.62	0.63	0.64	0.66
	LDB	37.9	40.0	43.0	48.0	41.7	43.9	47.9	52.9	45.8	49.8	54.2	58.6
	LWB	33.8	37.0	42.0	48.0	37.0	41.3	47.0	52.9	41.1	46.5	52.1	58.0
75	TCG	6.9	8.0	9.3	10.0	7.7	8.9	9.7	10.5	8.5	9.5	10.3	11.0
	SHG	6.1	5.8	5.5	4.9	7.0	6.6	6.1	5.3	8.5	7.7	6.7	5.7
	TC	6.8	7.9	9.1	9.9	7.5	8.8	9.6	10.4	8.4	9.4	10.2	10.9
	kW	0.77	0.79	0.80	0.81	0.78	0.80	0.81	0.83	0.80	0.81	0.82	0.84
	CMP	0.67	0.69	0.71	0.72	0.68	0.71	0.71	0.73	0.70	0.71	0.72	0.74
	LDB	39.4	42.0	44.3	48.7	43.1	45.3	48.7	53.3	46.7	50.3	54.4	58.8
	LWB	35.4	38.9	42.7	48.6	38.4	42.2	47.5	53.3	42.3	47.0	52.4	58.2
85	TCG	6.5	7.5	8.9	9.7	7.1	8.4	9.4	10.3	8.0	9.2	10.0	10.8
	SHG	5.9	5.5	5.3	4.8	6.7	6.3	5.9	5.2	8.0	7.5	6.6	5.6
	TC	6.4	7.4	8.8	9.6	7.0	8.2	9.3	10.1	7.9	9.0	9.9	10.7
	kW	0.85	0.87	0.89	0.90	0.86	0.89	0.90	0.92	0.88	0.90	0.91	0.93
	CMP	0.75	0.77	0.80	0.81	0.77	0.79	0.80	0.82	0.78	0.80	0.81	0.83
	LDB	40.7	43.9	45.7	49.7	44.6	47.0	49.7	53.8	48.4	51.0	54.9	59.2
	LWB	37.0	40.7	43.9	49.3	39.9	43.6	48.3	53.8	43.1	47.7	52.9	58.5
95	TCG	6.1	7.0	8.4	9.4	6.7	7.8	9.0	9.9	7.6	8.7	9.1	10.4
	SHG	5.7	5.2	5.0	4.6	6.5	6.0	5.7	5.0	7.6	7.2	6.1	5.4
	TC	6.0	6.9	8.3	9.3	6.6	7.7	8.9	9.8	7.5	8.6	9.0	10.3
	kW	0.94	0.96	0.98	1.00	0.95	0.98	1.00	1.02	0.97	0.99	1.01	1.03
	CMP	0.84	0.86	0.89	0.91	0.86	0.88	0.90	0.92	0.88	0.89	0.91	0.93
	LDB	42.1	45.6	47.6	50.8	45.8	48.7	50.8	54.7	50.0	52.1	55.6	59.7
	LWB	38.5	42.5	45.6	50.4	41.2	45.2	49.2	54.6	43.9	48.5	53.6	59.0
105	TCG	5.6	6.6	7.8	9.0	6.3	7.2	8.5	9.5	7.2	8.0	8.9	10.0
	SHG	5.5	5.0	4.7	4.4	6.3	5.7	5.4	4.8	7.2	6.8	6.0	5.2
	TC	5.5	6.5	7.7	8.9	6.1	7.1	8.4	9.3	7.1	7.9	8.8	9.9
	kW	1.03	1.06	1.08	1.11	1.05	1.07	1.10	1.12	1.07	1.09	1.12	1.14
	CMP	0.94	0.96	0.99	1.02	0.95	0.98	1.01	1.03	0.97	0.99	1.02	1.04
	LDB	43.5	47.0	49.6	52.2	46.9	50.3	52.4	55.6	51.6	53.7	56.5	60.5
	LWB	40.3	43.9	47.4	51.5	42.4	46.6	50.4	55.6	44.7	49.8	54.4	59.7
115	TCG	5.3	6.1	7.2	8.5	5.9	6.6	7.8	8.9	6.8	7.3	8.5	9.4
	SHG	5.3	4.8	4.4	4.1	5.9	5.4	5.0	4.6	6.8	6.4	5.9	5.0
	TC	5.1	5.9	7.0	8.4	5.8	6.5	7.7	8.8	6.7	7.2	8.4	9.3
	kW	1.14	1.16	1.19	1.23	1.16	1.18	1.21	1.24	1.18	1.19	1.23	1.26
	CMP	1.04	1.06	1.10	1.13	1.06	1.08	1.12	1.15	1.08	1.10	1.14	1.16
	LDB	45.1	48.7	51.7	53.8	48.9	51.9	54.3	57.0	53.5	55.0	57.5	61.3
	LWB	41.5	45.7	49.4	53.0	43.4	48.1	52.0	56.6	45.6	50.9	55.3	60.4

Rating Condition

*Refer to Systems Index Table on page

Not recommended for long-term operation

NOTES:

1. Direct interpolation is permissible. Do not extrapolate.
2. The SHG is based on 80 F edb temperature of air entering indoor coil.
Below 80 F edb, subtract (corr factor x cfm) from SHG.
Above 80 F edb, add (corr factor x cfm) to SHG.
Correction Factor = 1.10 x (1 - BF) x (edb - 80).

LEGEND

BF - Bypass Factor
CMP - Compressor
Edb - Entering Dry Bulb
Ewb - Entering Wet Bulb
kW - Total Power
LDB - Leaving Dry Bulb
LWB - Leaving Wet Bulb
SHG - Gross Sensible Capacity (1000 Btu/hour)
TC - Total Net Cooling Capacity (1000 Btu/hour)
TCG - Gross Cooling Capacity (1000 Btu/hour)

Cooling Capacities
38HDV012 with 40QNC012

Temp (F) Air Entering Condenser (Edb)		Air Entering Evaporator - Cfm/BF											
		135/0.04				235/0.04				340/0.05			
		Air Entering Evaporator - Ewb (F)											
		57	62	67	72	57	62	67	72	57	62	67	72
55	TCG	9.2	10.1	11.0	11.5	11.1	11.7	12.0	12.2	11.8	12.0	12.3	12.5
	SHG	7.8	7.2	6.6	5.6	10.0	8.6	7.0	5.7	11.0	9.0	7.4	5.9
	TC	9.0	9.9	10.9	11.3	11.0	11.5	11.8	12.1	11.6	11.9	12.1	12.4
	kW	0.80	0.83	0.83	0.84	0.83	0.84	0.85	0.85	0.84	0.85	0.85	0.85
	CMP	0.70	0.72	0.73	0.74	0.73	0.74	0.74	0.74	0.74	0.74	0.75	0.75
	LDB	24.1	28.8	33.2	40.9	38.5	44.7	51.7	57.5	48.5	54.4	59.4	63.9
	LWB	23.2	27.8	32.9	40.8	35.2	41.5	48.4	55.3	41.9	48.3	54.6	60.8
65	TCG	8.7	9.8	10.8	11.6	11.2	11.8	12.2	12.5	11.9	12.3	12.5	12.8
	SHG	7.5	7.0	6.3	5.7	10.3	8.9	7.3	5.9	11.4	9.6	7.7	6.1
	TC	8.6	9.6	10.7	11.4	11.0	11.6	12.1	12.4	11.7	12.1	12.4	12.7
	kW	0.89	0.92	0.93	0.94	0.93	0.94	0.95	0.96	0.95	0.95	0.96	0.96
	CMP	0.79	0.81	0.83	0.84	0.83	0.84	0.85	0.85	0.84	0.85	0.85	0.86
	LDB	26.2	30.1	35.8	40.3	37.2	43.6	50.5	56.9	47.2	52.7	58.5	63.4
	LWB	25.4	29.1	33.8	40.3	35.1	41.3	47.9	54.8	41.7	47.9	54.2	60.5
75	TCG	8.2	9.3	10.7	11.3	10.6	11.6	12.2	12.6	11.8	12.3	12.6	12.9
	SHG	7.2	6.7	6.2	0.1	9.9	8.9	7.4	5.9	11.3	9.9	7.9	6.2
	TC	8.1	9.2	10.6	11.2	10.4	11.5	12.1	12.5	11.6	12.1	12.5	12.8
	kW	0.99	1.01	1.04	1.1	1.03	1.05	1.06	1.07	1.05	1.06	1.07	1.07
	CMP	0.88	0.91	0.94	0.95	0.93	0.95	0.96	0.96	0.95	0.96	0.97	0.97
	LDB	28.5	32.1	36.7	41.5	38.8	43.4	50.1	56.6	47.4	51.9	57.8	63.1
	LWB	27.7	31.2	34.3	41.3	36.6	41.6	47.9	54.7	41.9	47.9	54.2	60.4
85	TCG	7.7	8.9	10.3	11.0	10.0	11.1	12.0	12.5	11.5	12.0	12.5	12.9
	SHG	6.9	6.5	6.0	5.4	9.6	0.1	7.4	5.8	11.4	9.9	8.1	6.3
	TC	7.5	8.7	10.2	10.9	9.8	11.0	11.9	12.4	11.3	11.9	12.3	12.7
	kW	1.09	1.11	1.14	1.16	1.14	1.2	1.17	1.19	1.16	1.17	1.19	1.19
	CMP	0.98	1.01	1.04	1.06	1.03	1.06	1.07	1.08	1.06	1.07	1.08	1.09
	LDB	30.7	33.7	37.6	42.7	40.1	44.5	49.9	57.1	47.1	51.7	57.4	62.9
	LWB	30.0	33.0	35.9	42.4	38.0	42.7	48.3	54.8	42.4	48.3	54.3	60.4
95	TCG	7.2	8.3	9.7	10.6	9.4	10.6	11.6	12.2	11.1	11.6	12.2	12.6
	SHG	6.6	6.2	5.8	5.2	9.2	8.4	7.3	5.8	11.1	9.8	8.1	6.3
	TC	7.0	8.2	9.6	10.5	9.3	10.5	11.5	12.1	10.9	11.4	12.0	12.5
	kW	1.19	1.22	1.25	1.27	1.25	1.27	1.29	1.31	1.28	1.29	1.33	1.33
	CMP	1.09	1.12	1.15	1.17	1.15	1.17	1.19	1.20	1.17	1.19	1.22	1.22
	LDB	32.9	36.0	39.3	44.1	41.8	45.7	50.5	56.9	48.1	52.0	57.3	62.9
	LWB	32.3	35.3	38.4	43.8	39.3	43.8	49.1	55.3	43.0	48.9	54.6	60.7
105	TCG	6.6	7.8	9.1	10.2	8.8	9.9	11.1	11.8	10.5	11.0	11.7	12.2
	SHG	6.2	5.9	5.5	5.0	8.8	8.1	7.1	5.7	10.5	9.7	8.0	6.2
	TC	6.4	7.6	9.0	10.0	8.6	9.8	10.9	11.6	10.4	10.8	11.5	12.0
	kW	1.31	1.34	1.37	1.39	1.37	1.38	1.41	1.43	1.40	1.41	1.43	1.44
	CMP	1.20	1.24	1.27	1.29	1.26	1.28	1.31	1.33	1.30	1.31	1.33	1.34
	LDB	35.3	38.2	41.4	45.8	43.5	46.9	51.4	57.3	49.7	52.4	57.6	63.2
	LWB	34.8	37.6	40.6	45.5	40.6	45.2	50.1	56.0	43.7	49.6	55.2	61.2
115	TCG	6.0	7.2	8.5	9.7	8.3	8.7	10.4	11.1	10.0	10.2	11.0	11.5
	SHG	5.9	5.6	0.1	4.7	0.1	0.1	6.8	5.5	10.0	9.4	7.7	5.9
	TC	5.9	7.1	8.4	9.5	8.2	8.6	10.3	11.0	9.8	10.1	10.9	11.3
	kW	1.43	1.46	1.5	1.52	1.5	1.5	1.54	1.56	1.52	1.53	1.55	1.57
	CMP	1.33	1.36	1.39	1.41	1.39	1.39	1.43	1.45	1.42	1.43	1.45	1.46
	LDB	37.7	40.3	43.4	47.8	45.6	46.8	52.6	58.2	51.2	53.2	58.4	63.8
	LWB	37.0	39.7	42.8	47.2	41.7	45.2	51.3	57.1	44.5	50.6	56.0	61.9

Rating Condition

*Refer to Systems Index Table on page

Not recommended for long-term operation

NOTES:

1. Direct interpolation is permissible. Do not extrapolate.
2. The SHG is based on 80 F edb temperature of air entering indoor coil.
Below 80 F edb, subtract (corr factor x cfm) from SHG.
Above 80 F edb, add (corr factor x cfm) to SHG.
Correction Factor = 1.10 x (1 - BF) x (edb - 80).

LEGEND

BF - Bypass Factor
CMP - Compressor
Edb - Entering Dry Bulb
Ewb - Entering Wet Bulb
kW - Total Power
LDB - Leaving Dry Bulb
LWB - Leaving Wet Bulb
SHG - Gross Sensible Capacity (1000 Btu/hour)
TC - Total Net Cooling Capacity (1000 Btu/hour)
TCG - Gross Cooling Capacity (1000 Btu/hour)

Cooling Capacities
38QRV009 with 40QNQ009

Temp (F) Air Entering Condenser (Edb)		Air Entering Evaporator - Cfm/BF											
		135/0.04				170/0.04				230/0.05			
		Air Entering Evaporator - Ewb (F)											
		57	62	67	72	57	62	67	72	57	62	67	72
55	TCG	7.8	8.7	9.4	9.9	8.5	9.2	9.8	10.3	9.1	9.6	10.1	10.5
	SHG	6.7	6.3	5.7	4.9	7.6	6.9	6.1	5.2	8.8	7.6	6.5	5.5
	TC	7.7	8.6	9.2	9.8	8.3	9.1	9.7	10.1	8.9	9.5	10.0	10.4
	kW	0.62	0.63	0.63	0.64	0.62	0.63	0.64	0.65	0.63	0.64	0.65	0.65
	CMP	0.53	0.53	0.53	0.54	0.53	0.53	0.54	0.55	0.53	0.54	0.55	0.56
	LDB	35.6	38.6	42.7	48.7	39.9	43.7	48.4	53.8	45.6	50.4	55.2	59.6
	LWB	31.8	36.4	42.3	48.7	36.1	41.4	47.4	53.8	41.1	46.8	52.7	58.9
65	TCG	7.3	8.5	9.3	10.0	8.2	9.0	9.7	10.3	8.8	9.6	10.2	10.7
	SHG	6.4	6.1	5.6	4.9	7.3	6.8	6.1	5.2	8.8	7.7	6.6	5.5
	TC	7.2	8.4	9.1	9.8	8.1	8.9	9.6	10.2	8.7	9.4	10.1	10.6
	kW	0.69	0.71	0.71	0.72	0.70	0.71	0.72	0.73	0.71	0.72	0.73	0.74
	CMP	0.60	0.61	0.61	0.63	0.61	0.61	0.62	0.63	0.61	0.62	0.63	0.64
	LDB	37.7	39.8	43.5	48.7	41.3	44.3	48.5	53.6	45.4	50.1	54.8	59.3
	LWB	33.7	37.2	42.7	48.7	36.9	41.9	47.5	53.6	41.6	46.9	52.6	58.7
75	TCG	6.9	8.0	9.0	9.8	7.6	8.7	9.5	10.3	8.5	9.3	10.1	10.7
	SHG	6.1	5.8	5.4	4.8	7.0	6.6	6.0	5.2	8.5	7.6	6.6	5.5
	TC	6.8	7.9	8.9	9.7	7.5	8.6	9.4	10.1	8.4	9.2	9.9	10.5
	kW	0.77	0.79	0.80	0.81	0.78	0.80	0.81	0.82	0.80	0.80	0.82	0.83
	CMP	0.68	0.69	0.70	0.71	0.69	0.70	0.71	0.72	0.70	0.71	0.72	0.73
	LDB	39.3	41.8	44.7	49.3	43.2	45.4	49.2	53.8	46.6	50.6	54.9	59.4
	LWB	35.5	38.9	43.4	49.2	38.6	42.7	48.0	53.8	42.2	47.4	52.8	58.7
85	TCG	6.4	7.5	8.7	9.5	7.1	8.3	9.2	10.0	8.0	8.9	9.8	10.5
	SHG	5.9	5.5	5.2	4.7	6.7	6.3	5.8	5.1	8.0	7.4	6.5	5.4
	TC	6.3	7.3	8.6	9.4	7.0	8.2	9.1	9.9	7.9	8.8	9.6	10.4
	kW	0.86	0.88	0.90	0.91	0.87	0.89	0.90	0.92	0.89	0.90	0.91	0.93
	CMP	0.76	0.78	0.80	0.81	0.77	0.79	0.81	0.82	0.79	0.80	0.81	0.83
	LDB	40.8	44.0	46.2	50.2	44.6	47.0	50.1	54.4	48.6	51.3	55.3	59.7
	LWB	37.2	40.9	44.6	50.0	40.0	43.8	48.8	54.4	43.2	48.1	53.3	59.0
95	TCG	6.0	6.9	8.3	9.2	6.5	7.7	8.8	9.7	7.5	8.4	9.2	10.1
	SHG	5.7	5.2	5.0	4.5	6.5	6.0	5.6	4.9	7.5	7.1	6.1	5.3
	TC	5.8	6.8	8.1	9.1	6.4	7.6	8.7	9.5	7.4	8.3	9.0	10.0
	kW	0.95	0.97	1.00	1.01	0.96	0.99	1.01	1.02	0.99	1.00	1.01	1.03
	CMP	0.85	0.88	0.90	0.92	0.87	0.89	0.91	0.92	0.89	0.90	0.92	0.94
	LDB	42.4	45.7	47.9	51.4	45.4	48.9	51.3	55.2	50.4	52.4	56.0	60.2
	LWB	39.0	42.7	46.0	51.0	41.6	45.4	49.8	55.1	44.1	48.9	54.0	59.4
105	TCG	5.5	6.5	7.7	8.7	6.2	7.1	8.3	9.2	7.1	7.8	8.8	9.7
	SHG	5.5	5.0	4.7	4.3	6.2	5.7	5.3	4.7	7.1	6.7	6.1	5.1
	TC	5.4	6.3	7.6	8.6	6.1	7.0	8.2	9.1	7.0	7.7	8.7	9.6
	kW	1.05	1.08	1.10	1.12	1.07	1.09	1.12	1.14	1.09	1.11	1.13	1.15
	CMP	0.96	0.98	1.00	1.03	0.97	0.99	1.02	1.04	0.99	1.01	1.03	1.05
	LDB	43.5	47.3	49.8	52.9	47.4	50.5	52.8	56.3	52.0	54.0	56.8	60.9
	LWB	40.6	44.3	47.8	52.3	42.6	46.9	51.0	56.1	44.9	50.1	54.8	60.1
115	TCG	5.2	5.9	7.0	8.2	5.8	6.4	7.7	8.7	6.7	7.1	8.2	9.1
	SHG	5.2	4.7	4.3	4.0	5.8	5.3	5.0	4.4	6.7	6.3	5.8	4.9
	TC	5.0	5.8	6.9	8.1	5.7	6.3	7.6	8.5	6.6	7.0	8.1	9.0
	kW	1.17	1.19	1.22	1.24	1.19	1.20	1.23	1.26	1.21	1.22	1.25	1.27
	CMP	1.07	1.09	1.12	1.15	1.09	1.11	1.14	1.16	1.11	1.12	1.15	1.17
	LDB	45.8	48.9	52.0	54.5	49.4	52.3	54.4	57.6	53.8	55.5	58.0	61.8
	LWB	41.8	46.1	49.8	53.8	43.6	48.6	52.3	57.2	45.8	51.3	55.8	60.9

Rating Condition

*Refer to Systems Index Table on page

Not recommended for long-term operation

NOTES:

1. Direct interpolation is permissible. Do not extrapolate.
2. The SHG is based on 80 F edb temperature of air entering indoor coil.
Below 80 F edb, subtract (corr factor x cfm) from SHG.
Above 80 F edb, add (corr factor x cfm) to SHG.
Correction Factor = 1.10 x (1 - BF) x (edb - 80).

LEGEND

BF - Bypass Factor
CMP - Compressor
Edb - Entering Dry Bulb
Ewb - Entering Wet Bulb
kW - Total Power
LDB - Leaving Dry Bulb
LWB - Leaving Wet Bulb
SHG - Gross Sensible Capacity (1000 Btu/hour)
TC - Total Net Cooling Capacity (1000 Btu/hour)
TCG - Gross Cooling Capacity (1000 Btu/hour)

Cooling Capacities
38QRV012 with 40QNQ012

Temp (F) Air Entering Condenser (Edb)		Air Entering Evaporator - Cfm/BF											
		135/0.04				235/0.04				340/0.05			
		Air Entering Evaporator - Ewb (F)											
		57	62	67	72	57	62	67	72	57	62	67	72
55	TCG	8.9	10.0	11.2	12.0	11.0	11.9	12.5	12.9	11.9	12.4	12.9	13.2
	SHG	7.3	7.0	6.6	5.9	9.9	8.9	7.8	6.6	11.1	9.8	8.3	6.9
	TC	8.8	9.9	11.1	11.8	10.9	11.7	12.3	12.8	11.7	12.3	12.7	13.0
	kW	0.61	0.62	0.62	0.63	0.62	0.63	0.63	0.64	0.63	0.63	0.64	0.64
	CMP	0.50	0.51	0.52	0.52	0.52	0.52	0.53	0.53	0.52	0.53	0.53	0.54
	LDB	30.1	33.0	35.9	41.5	41.2	45.2	50.0	55.2	49.7	53.7	58.1	62.0
	LWB	26.4	30.2	34.7	41.3	36.9	42.4	48.7	55.2	42.7	48.6	54.7	60.8
65	TCG	8.4	9.5	11.0	11.9	10.7	11.7	12.5	13.2	11.6	12.5	13.1	13.5
	SHG	7.8	7.0	6.5	5.7	10.7	9.3	8.1	6.8	11.6	10.9	8.9	7.1
	TC	8.3	9.4	10.9	11.8	10.6	11.6	12.4	13.0	11.5	12.3	12.9	13.4
	kW	0.68	0.69	0.70	0.71	0.70	0.71	0.72	0.72	0.71	0.72	0.72	0.73
	CMP	0.57	0.59	0.60	0.61	0.60	0.60	0.61	0.62	0.60	0.61	0.62	0.62
	LDB	32.1	35.5	37.1	41.9	42.3	45.5	49.9	54.9	48.3	53.2	57.6	61.6
	LWB	28.6	32.4	35.5	41.5	37.5	42.7	48.6	54.9	43.1	48.5	54.4	60.5
75	TCG	7.9	9.0	10.6	11.7	10.1	11.4	12.3	13.1	11.3	12.2	13.0	13.6
	SHG	7.3	6.7	6.2	5.6	10.1	9.0	7.9	6.7	11.2	10.6	8.9	7.2
	TC	7.7	8.9	10.4	11.5	9.9	11.2	12.2	13.0	11.1	12.0	12.9	13.4
	kW	0.75	0.77	0.78	0.80	0.78	0.79	0.80	0.81	0.79	0.80	0.81	0.82
	CMP	0.65	0.67	0.68	0.69	0.68	0.69	0.70	0.71	0.69	0.70	0.71	0.72
	LDB	34.2	37.5	39.1	43.0	44.2	46.4	50.4	55.0	49.3	53.3	57.5	61.6
	LWB	30.8	34.5	37.2	42.3	38.9	43.4	49.0	55.0	43.6	48.9	54.5	60.4
85	TCG	7.4	8.6	9.9	11.3	9.4	10.9	11.9	12.8	10.7	11.7	12.7	13.4
	SHG	6.9	6.4	5.8	5.4	9.3	8.6	7.7	6.6	10.7	10.2	8.7	7.1
	TC	7.3	8.5	9.8	11.2	9.2	10.7	11.8	12.7	10.6	11.6	12.5	13.3
	kW	0.84	0.85	0.87	0.89	0.87	0.88	0.89	0.91	0.88	0.89	0.90	0.92
	CMP	0.73	0.75	0.77	0.78	0.76	0.78	0.79	0.80	0.77	0.79	0.80	0.81
	LDB	36.2	38.8	41.5	44.4	46.0	47.7	51.2	55.4	50.7	53.8	57.8	61.8
	LWB	32.9	36.1	39.5	43.6	40.5	44.4	49.7	55.4	44.3	49.5	54.9	60.6
95	TCG	6.9	8.0	9.3	10.8	8.7	10.2	11.4	12.4	10.1	11.1	12.2	13.0
	SHG	6.4	5.9	5.5	5.2	8.7	8.0	7.3	6.4	10.1	9.7	8.3	6.8
	TC	6.7	7.9	9.2	10.7	8.5	10.0	11.2	12.2	10.0	11.0	12.0	12.8
	kW	0.93	0.95	0.96	0.98	0.96	0.97	0.99	1.00	0.97	0.98	1.00	1.02
	CMP	0.82	0.84	0.86	0.88	0.85	0.87	0.88	0.90	0.87	0.88	0.90	0.91
	LDB	38.2	41.0	43.7	46.2	47.4	49.4	52.2	56.1	52.4	54.6	58.3	62.3
	LWB	35.1	38.3	41.7	45.3	41.8	45.8	50.6	56.1	45.1	50.2	55.4	61.0
105	TCG	6.3	7.4	8.7	10.3	8.1	9.4	10.8	11.8	9.5	10.4	11.5	12.4
	SHG	5.9	5.5	5.1	4.9	8.0	7.4	6.9	6.0	9.5	9.0	7.9	6.5
	TC	6.2	7.3	8.6	10.1	7.9	9.3	10.6	11.6	9.4	10.2	11.3	12.2
	kW	1.02	1.04	1.06	1.08	1.05	1.07	1.09	1.11	1.07	1.08	1.10	1.12
	CMP	0.92	0.94	0.96	0.97	0.95	0.96	0.98	1.00	0.97	0.98	1.00	1.02
	LDB	40.0	43.1	45.9	48.0	48.4	51.0	53.5	57.2	54.0	55.6	59.1	63.0
	LWB	37.2	40.5	43.8	47.1	43.1	47.2	51.7	57.1	45.9	51.1	56.2	61.6
115	TCG	5.7	6.8	8.2	9.6	7.5	8.6	10.0	11.0	9.0	9.5	10.7	11.6
	SHG	5.3	5.0	4.8	4.6	7.5	6.8	6.4	5.7	8.9	8.3	7.3	6.1
	TC	5.6	6.7	8.0	9.5	7.4	8.5	9.9	10.9	8.8	9.4	10.5	11.5
	kW	1.13	1.14	1.16	1.18	1.16	1.17	1.19	1.21	1.18	1.18	1.21	1.23
	CMP	1.02	1.04	1.06	1.08	1.05	1.06	1.09	1.11	1.07	1.08	1.10	1.12
	LDB	42.1	45.1	47.7	50.0	50.4	52.6	54.9	58.5	55.7	56.7	59.9	63.8
	LWB	39.5	42.6	45.7	49.1	44.1	48.6	52.9	58.1	46.6	52.0	57.0	62.3

Rating Condition

*Refer to Systems Index Table on page

Not recommended for long-term operation

NOTES:

- Direct interpolation is permissible. Do not extrapolate.
- The SHG is based on 80 F edb temperature of air entering indoor coil.
Below 80 F edb, subtract (corr factor x cfm) from SHG.
Above 80 F edb, add (corr factor x cfm) to SHG.
Correction Factor = $1.10 \times (1 - BF) \times (edb - 80)$.

LEGEND

BF - Bypass Factor
CMP - Compressor
Edb - Entering Dry Bulb
Ewb - Entering Wet Bulb
kW - Total Power
LDB - Leaving Dry Bulb
LWB - Leaving Wet Bulb
SHG - Gross Sensible Capacity (1000 Btu/hour)
TC - Total Net Cooling Capacity (1000 Btu/hour)
TCG - Gross Cooling Capacity (1000 Btu/hour)