

**Product Specifications** 

# ASHRAE 90.1 COMPLIANT PACKAGE GAS HEATING/ELECTRIC COOLING, R-410A SINGLE PACKAGE ROOFTOP 17.5 - 25 TONS

# BUILT TO LAST, EASY TO INSTALL AND SERVICE

- One-piece, high efficiency gas heating and electric cooling with a low profile, prewired, tested, and charged at the factory
- Dedicated vertical or horizontal air flow duct configuration models. No field kits required.
- Full perimeter base rail with built-in rigging adapters and fork truck slots
- Pre-painted exterior panels and primer-coated interior panels tested to 500 hours salt spray protection
- Fully insulated cabinet
- Two-stage cooling with independent circuits and control on all models
- Redundant gas valve for two stage gas heating capacity control
- Exclusive IGC solid-state control for on-board diagnostics with LED error code designation, burner control logic and energy saving indoor fan motor delay
- · High efficiency, gas heat with induced draft flue exhaust design
- · Scroll compressors with internal line-break connections on all models
- All units have high and low pressure switches
- Two inch disposable fiberglass type return air filters in dedicated rack with tool-less filter access door
- Refrigerant circuits contain a liquid line filter drier to trap dirt and moisture
- Round tube plate fin evaporator and condenser coil design
- Exclusive non-corrosive composite condensate pan in accordance with ASHRAE 62 Standard, sloping design; end drain
- Belt drive evaporator-fan motor and pulley combinations available to meet most applications
- Access panels with easy grip handles provide quick and easy access to the blower and blower motor, control box, and compressors.
- "No-strip" screw system has superior holding power and guides screws into position while preventing the screw from stripping the unit's metal.
- Newly designed terminal board facilitates simple safety circuit troubleshooting and simplified control box arrangement
- Standard outdoor temperature cooling operation range up to 115°F (46°C) and down to 30°F (–1°C )
- Fixed orifice metering devices on all models to precisely control refrigerant flow
- Large, laminated control wiring and power wiring drawings are affixed to
- unit to make troubleshooting easy
- Single point gas and electrical connections

# WARRANTY

- 15 Year limited warranty on optional stainless steel heat exchanger.
  10 Year limited warranty on aluminized stainless steel heat exhanger
- 5 Year compressor limited warranty

• 1 Year parts limited warranty



17.5 Ton



20 & 25 Ton



Use of the AHRI Certified TM Mark indicates a manufacturer's participation in the program. For verification of certification for individual products, go to www.ahridirectory.org.



ASHRAF

COMPLIANT

UNIT PERFORMANCE DATA – Two Stage Cooling								
			COOLI	NG	GAS HEATIN	IG		Unit
UNIT	Dedicated Airflow	Nominal Tons	Net Cap. (Btuh)	EER	Input Cap. (Btuh) Stage 2	AFUE %	Unit Dimensions H x W x L	Weight Ib. [kg]
RGS210*^AA0AAA	Vertical	17.5	208,000	10.8	220,000 - 400,000	81.0	49-3/8" x 86-5/8" x 127-7/8"	2286 [1037]
RGS213*^AA0AAA	Horizontal	17.5	208,000	10.8	220,000 - 400,000	81.0	49-3/8" x 86-5/8" x 127-7/8"	2286 [1037]
RGS240*^AA0AAA	Vertical	20	242,000	9.8	220,000 - 400,000	81.0	49-3/8" x 86-5/8" x 141-1/2"	2436 [1105]
RGS243*^AA0AAA	Horizontal	20	242,000	9.8	220,000 - 400,000	81.0	49-3/8" x 86-5/8" x 141-1/2"	2436 [1105]
RGS300*^AA0AAA	Vertical	25	282,000	9.8	220,000 - 400,000	81.0	57-3/8" x 86-5/8" x 141-1/2"	2561 [1162]
RGS303*^AA0AAA	Horizontal	25	282,000	9.8	220,000 - 400,000	81.0	57-3/8" x 86-5/8" x 141-1/2"	2561 [1162]

\* Indicates Unit voltage: H = 208/230-3-60, L = 460-3-60, S = 575-3-60

^ See model nomenclature listing for gas heating options.

NOTE: BASE MODEL NUMBERS LISTED. SEE MODEL NOMENCLATURE LISTING FOR ADDITIONAL OPTIONS

# **TABLE OF CONTENTS**

PAGE	
MODEL NUMBER NOMENCLATURE 3	
FACTORY OPTIONS AND/OR ACCESSORIES 4	
ARI COOLING RATING TABLE	
SOUND PERFORMANCE TABLE 8	
HEAT RATING TABLES 9	
PHYSICAL DATA 10	
CURBS & WEIGHTS DIMENSIONS 13	
APPLICATION DATA 20	

	PAG	iΕ
COOLING TABLES		21
STATIC PRESSURE ADDERS		24
FAN PERFORMANCE		25
OUTDOOR AIR INTAKE & EXHAUST PERF		30
ELECTRICAL INFO		31
MCA / MOCP		32
TYPICAL WIRING DIAGRAMS		33
SEQUENCE OF OPERATION		35
GUIDE SPECIFICATIONS		36

# MODEL NOMENCLATURE

MODEL SERIES	R	G	S	2	1	0	Н	D	Α	В	0	Α	Α	Α
Position Number	1	2	3	4	5	6	7	8	9	10	11	12	13	14
R = Rooftop	J													
A = Air Conditioning (Cooling Only)		ļ												
G = Gas/Electric		Туре												
S = Standard ASHRAE 90.1-2010 Efficiency														
210 = 210,000 = 17.5 Tons Dedicated Vertical			-		oturn Air	1								
213 = 210,000 = 17.5 Tons Dedicated Venical			ihhià Vii	, na = n		)								
240 = 240,000 = 20 Tons Dedicated Vertical S		17												
243 = 240,000 = 20 Tons Dedicated Vertical C 243 = 240,000 = 20 Tons Dedicated Horizonta														
300 = 300,000 = 25 Tons Dedicated Vertical S														
303 = 300,000 = 25 Tons Dedicated Horizonta														
	21 O/ 41 U		Nor	ninal Co	oling Ca	pacity								
H 008/020 2 60					<u>9</u> 00		J							
H = 208/230-3-60														
L = 460-3-60							lalta							
S = 575-3-60							/oltage	J						
D = Low Heat														
E = Medium Heat														
F = High Heat														
S = Low Heat, Stainless Steel Heat Exchange														
R = Medium Heat, Stainless Steel Heat Excha	-													
T = High Heat, Stainless Steel Heat Exchange	er						- <b>i</b> '							
A Standard Statio Option (All models)						He	ating Ca	ipacity	ļ					
A = Standard Static Option (All models) C = Medium Static Option (17.5 Ton Only)														
F = Medium Static High Efficiency Option (20	8 25 To	n Only)												
E = High Static High Efficiency Option (All Mo		i Oniy)						Motor	Ontion					
A = None	ueisj							MOLOI	opuon	ļ				
B = Economizer w/Bara-relief, OA Temp sens	sor													
E = Economizer w/Bara-relief + CO2 sensor,		p sensor												
H = Economizer w/Bara-relief, Enthalpy sens														
L = Economizer w/Bara-relief + CO <sub>2</sub> sensor,		sensor												
P = 2-Position damper w/Baro-relief							Outdoo	r Air Op	tions / C	Control				
0A = No Options								•			J	I		
4B = Non-fused Disconnect														
AT = Non-powered 115v Convenience Outlet.														
BR = Supply Air Smoke Detector	-													
7C = Non-fused Disconnect + Non-powered	115v Co	nveniena	e Outlet	t.										
7K = Non-fused Disconnect + Non-powered					ly Air Sm	noke Det	tector							
BA = Non-fused Disconnect + Supply Air Sm					•				Fac	ctory Ins	stalled O	ptions		
A = Alum / Cu Cond & Alum / Cu Evap										•		•	ļ	
-	Evan													
B = Pre coated Alum / Cu Cond & Alum / Cu Evap														
C = E-coatedd Alum / Cu Cond & Alum / Cu Evap D = E-coated Alum / Cu Cond & E-coated Alum / Cu Evap														
E = Cu / Cu Cond & Alum / Cu Evap		Lvap												
F = Cu / Cu Cond, Cu / Cu Evap								Cond	lenser /	Fvanora	ator Coil	Config	uration	
								30110		-vupuid		Johnna	a uuvii	1
A = Original Design													• ·	es Digit

Table 1 – FACTORY INSTALLED OPTIONS AND FIELD INSTALLED ACCESSORIES
---

CATEGORY	ITEM	FACTORY INSTALLED OPTION	FIELD INSTALLED ACCESSORY
Cabinet	Dedicated Vertical Air Flow Duct Configuration	Х	
Cabinet	Dedicated Horizontal Air Flow Duct Configuration	Х	
	Cu/Cu (indoor) Coils	Х	
Coil Options	Pre-Coat (outdoor) Coils	Х	
	E-coated (outdoor & indoor) coils	Х	
Condenser Protection	Condenser coil hail guard (louvered design)		Х
	Smoke detector (supply air)	Х	Х
Controls	Time Guard II compressor delay control circuit		Х
	Phase Monitor		Х
	Economizer	Х	Х
Economizers	Motorized 2 position outdoor-air damper	Х	Х
& Outdoor Air	Manual outdoor-air damper (25%)		Х
Dampers	Barometric relief <sup>1</sup>	Х	Х
	Barometric hood (Horizontal economizer)		Х
	Power exhaust-centrifugal blower		Х
	Single dry bulb temperature sensors <sup>2</sup>	Х	Х
Economizer Sensors	Single enthalpy sensors <sup>2</sup>	Х	Х
&	Differential enthalpy sensors <sup>2</sup>		Х
IAQ Devices	Duct mounted CO <sub>2</sub> sensor <sup>2</sup>		Х
	4-in Filter Track Assembly		Х
	Propane conversion kit		Х
One linet	Stainless steel heat exchanger	Х	
Gas Heat	High altitude conversion kit		Х
	Flue Discharge Deflector		Х
Indoor Motor & Drive	Multiple motor and drive packages	Х	
Low Ambient	Winter start kit <sup>3</sup>		Х
Control	Motormaster head pressure controller <sup>3</sup>		Х
Power	Convenience outlet (unpowered)	Х	
Options	Non-fused disconnect <sup>4</sup>	Х	
Deef Curbe	Roof curb 14-in (356mm)		Х
Roof Curbs	Roof curb 24-in (610mm)		Х

### NOTES:

1. Included with economizer.

2. Sensors used to optimize economizer performance.

3. See application data for assistance.

3. Non-fused disconnect switch cannot be used when MOCP electrical rating exceeds 70 amps at 460/575 volt and 150 amps at 208/230 volt.

# FACTORY OPTIONS AND/OR ACCESSORIES

## Economizer (dry-bulb or enthalpy)

Economizers save money. They bring in fresh, outside air for ventilation; and provide cool, outside air to cool your building. This is the preferred method of low-ambient cooling. When coupled to  $CO_2$  sensors, economizers can provide even more savings by coupling the ventilation air to only that amount required.

Economizers are available, installed and tested by the factory, with either enthalpy or dry-bulb temperature inputs. Additional sensors are available as accessories to optimize the economizers.

Economizers include gravity controlled, barometric relief equalizes building pressure and ambient air pressures. This can be a cast effective solution to prevent building pressurization. If further control of exhaust air is required, a dual centrifugal fan power exhaust system is also available.

### CO<sub>2</sub> Sensor

Improves productivity and saves money by working with the economizer to intake only the correct amount of outside air for ventilation. As occupants fill your building, the  $CO_2$  sensor detects their presence through increasing  $CO_2$  levels, and opens the economizer appropriately.

When the occupants leave, the  $CO_2$  levels decrease, and the sensor appropriately closes the economizer. This intelligent control of the ventilation air, called Demand Control Ventilation (DCV) reduces the overall load on the rooftop, saving money.

# FACTORY OPTIONS AND/OR ACCESSORIES (CONT.)

### **Smoke Detector**

Smoke detectors make your application safer and your job easier. Smoke detectors immediately shut down the rooftop unit when smoke is detected. It is available for supply air.

### Louvered Hail Guards (accessory only)

Sleek, louvered panels protect the condenser coil from hail damage, foreign objects, and incidental contact.

# **Convenience Outlet (un-powered)**

Reduce service and/or installation costs by including a convenience outlet in your specification. The convenience outlet provides, 15 amp, 115v GFCI receptacle with "Wet in Use" cover. This option is to be powered from a separate 115/120v power source.

## **Non-Fused Disconnect**

This OSHA–compliant, factory–installed, safety switch allows a service technician to locally secure power to the rooftop capable of providing protection to a MOCP maximum of 200A.

### Power Exhaust with Barometric Relief

Superior internal building pressure control. This field-installed accessory may eliminate the need for costly, external pressure control fans.

### **Time Guard II Control Circuit**

This accessory protects your compressor by preventing short–cycling in the event of some other failure, prevents the compressor from restarting for 30 seconds after stopping.

### **Motorized 2-Position Damper**

The new 2-position, motorized outdoor air damper admits up to 100% outside air. Using reliable, gear-driven technology, the 2-position damper opens to allow ventilation air and closes when the rooftop stops, stopping unwanted infiltration.

### Manual OA Damper (accessory only)

Manual outdoor air dampers are an economical way to bring in ventilation air. The dampers are available in 25% versions.

#### Motormaster Head Pressure Controller

The Motormaster motor controller is a low ambient, head pressure controller kit that is designed to maintain the unit's condenser head pressure during periods of low ambient cooling operation. This device should be used as an alternative to economizer free cooling not when economizer usage is either not appropriate or desired. The Motormaster will either cycle the outdoor-fan motors or operate them at reduced speed to maintain the unit operation, depending on the model.

### Winter Start Kit (accessory only)

The winter start kit extends the low ambient limit of your rooftop to  $25^{\circ}$ F ( $-4^{\circ}$ C). The kit bypasses the low pressure switch, preventing nuisance tripping of the low pressure switch. Other low ambient precautions may still be prudent.

### Propane Heating (accessory only)

Convert your gas heat rooftop from standard natural gas operation to propane using this field-installed kit.

### High Altitude Heating (accessory only)

High altitudes have less oxygen, which means heat exchangers need less fuel. The new gas orifices in this field-installed kit make the necessary adjustment for high altitude applications. They restore the optimal fuel to air mixture and maintain healthy combustion at altitudes above 2000 ft (610m). Kits may not be required in all areas.

### **Optional Stainless Steel Heat Exchanger**

The stainless steel heat exchanger option provides the tubular heat exchanger be made out of a minimum 20 gauge type 409 stainless steel for applications where the mixed air to the heat exchanger is expected to drop below  $45^{\circ}F$  (7°C). Stainless steel may be specified on applications where the presence of airborne contaminants require its use or in area with very high outdoor humidity that may result in severe condensation in the heat exchanger during cooling operation.

### Flue Discharge Deflector (accessory only)

The flue discharge deflector is a useful accessory when flue gas recirculation is a concern. By venting the flue discharge upwards, the deflector minimizes the chance for a neighboring unit to intake the flue exhaust.

### **High Static Motors and Drives**

Some applications need larger horsepower motors, some need more airflow, and some need both. A wide selection of motors and pulleys (drives) are available, factory installed, to handle nearly any application.

#### **Filter or Fan Status Switches**

Use these differential pressure switches to detect a filter clog or indoor fan motor failure. When used in conjunction with a compatible unit controller/thermostat, the switches will activate an alarm to warn the appropriate personnel.

### **Barometric Hood (accessory only)**

For Horizontal Economizer applications where relief damper is installed in duct work. This kit provides the needed protection.

# ACCESSORIES - RGS210-313

FLAT ROOF CURBS*		
Model Number	Description	Use With Model Size
CRRFCURB045A00	14" High Roof Curb – Vertical and Horizontal Economizer IV with solid-state controller, gear-driven, modulating damper, spring	210/213
CRRFCURB047A00	return actuator, up to 100% barometric relief, supply and outdoor air sensors and outdoor air hood. CO2 sensor compatible.	240/243 - 300/303
CRRFCURB046A00	24" High Roof Curb – Vertical and Horizontal Economizer IV with solid-state controller, gear-driven, modulating damper, spring	210/213
CRRFCURB048A00	return actuator, up to 100% barometric relief, supply and outdoor air sensors and outdoor air hood. CO2 sensor compatible.	240/243 - 300/303

\* Includes thru-the-bottom capability

ECONOMIZERS				
Model Number	Description	Use With Model Size		
DNECOMZR052A00	Vertical & Horizontal with solid state controller	210/213 - 240/243		
DNECOMZR053A00	Vertical & Horizontal with solid state controller	300/303		
ECONOMIZER SENSO	DRS			
Model Number	Description	Use With Model Size		
DNTEMPSN002A00	Single (dry bulb) Control	ALL Economizers		
DNCBDIOX005A00	CO2 Sensor and aspirator box for use in return air stream.	ALL Economizers		
DNENTDIF004A00	Return Air Enthalpy Sensor	ALL Economizers		
AXB078ENT	Enthalpy Control ALL			
BAROMETRIC RELIEI	HOOD			
Model Number	Description	Use With Model Size		
CRBARHOD001A00	For horizontal economizer applications where relief damper is installed in duct work, this kit provides needed protection	213 - 243 - 303		
POWER EXHAUST*				
Model Number	Description	Use With Model Size		
CRPWREXH068A00	Vertical and Horizontal, 208/230-3-60	210/213-240/243-300/303		
CRPWREXH069A00	Vertical and Horizontal, 460-3-60	210/213-240/243-300/303		
CRPWREXH070A00	Vertical and Horizontal, 575–3–60	210/213-240/243-300/303		

\* When power exhaust is used on horizontal applications, it must be field mounted to the side of the return duct.

MANUAL OUTDOOR	AIR DAMPERS			
Model Number	Description	Use With Model Size		
CRMANDPR009A00	25% Open Manual Fresh Air Damper	210/213 - 240/243		
CRMANDPR010A00	25% Open Manual Fresh Air Damper	300/303		
	DR AIR DAMPERS			
Model Number	Description	Use With Model Size		
CRTWOPOS012A00	Motorized 2 position outdoor air damper	210/213 - 240/243		
CRTWOPOS013A00	Motorized 2 position outdoor air damper	300/303		
LOW AMBIENT CONT	ROLS			
Model Number	Description	Use With Model Size		
CRLOWAMB041A00 <sup>1</sup>	Motormaster® I –20° Low Ambient Control 208/230–3–60	210/213-240/243-300/303		
CRLOWAMB042A00 <sup>1</sup>	Motormaster® I –20° Low Ambient Control 460–3–60, 575–3–60	210/213-240/243-300/303		
CRTRXKIT001A00	Motormaster® I –20° Transformer 575–3–60 Must be used in conjunction with Low Ambient Controller if used on 575–3–60 models.	210/213-240/243-300/303		

<sup>1</sup> Also requires one DNWINSTR001A00 winter start kit per circuit.

# ACCESSORIES - RGS210-313 (cont.)

	KIIS	
Model Number	Description	Use With Model Size
NRTIMEGD001A00	Time Guard II	210 – 303
CRSDTEST001A00	Smoke detector remote Test/Reset/Alarm indicator kit	210 – 303
CRPHASE3001A02	Electronic Phase Monitor - All 208/230/460-3-60 models	210 – 303
CRPHASE3002A00	Electronic Phase Monitor - All 575-3-60 models	210 – 303
CRSTATUS005A00	Fan/filter Status Switch – Indicator light not included	210 – 303
CRSMKSEN002A00	Smoke Detector Control Module	210 – 303
CRSMKKIT002A00	Smoke Detector Control Module (Smoke Detector Sensor with sampling tube & exhaust tube)	210 – 303
DNWINSTR001A00	Winter Start Kit – Contains time delay relay for timed bypass of low pressure switch on startup	210 – 303
PROPANE GAS CONVI	ERSION KITS	
Model Number	Description	Use With Model Size
CRLPKIT9001A00	Propane Conversion kit. for use between 0' to 2,000'	210 – 303
CRLPELEV005A00	Propane and Hi Altitude conversion kit. for use between 2001' to 10,000'	210 – 303
CRLPELEV006A00	Propane and Hi Altitude conversion kit. for use between 10,001' to 14,000/	210 – 303
NATURAL GAS HIGH A	ALTITUDE CONVERSION KITS	
Model Number	Description	Use With Model Size
CRNGELEV001A00	High Altitude Conversion kit. for use between 3,000' to 10,000'	210 – 303
CRNGELEV002A00	High Altitude Conversion kit. for use between 10,001' to 14,000'	210 – 303
HEATING UPGRADE K	ITS	
Model Number	Description	Use With Model Size
CRFLUEDS006A00	Flue Discharge Deflector	210 – 303
4" FILTER TRACK UPO	RADE KIT	
Model Number	Description	Use With Model Size
CRFLTTRK001A00	4" Field Conversion Kit	210 – 303
LOUVERED HAIL GUA	RDS	
Model Number	Description	Use With Model Size
CRLVHLGD017A00	Louvered Condenser Coil Hail Guard	210/213
CRLVHLGD027A00	Louvered Condenser Coil Hail Guard	240/243
CRLVHLGD028A00	Louvered Condenser Coil Hail Guard	300/303

# Table 2 – AHRI COOLING RATING TABLE

MODEL RGS	COOLING STAGES	NOMINAL CAPACITY (TONS)	NET COOLING CAPACITY (MBH)	TOTAL POWER (kW)	EER	IEER
210 – 213	2	17.5	208.0	19.3	10.8	11.9
240 – 243	2	20	242.0	24.7	9.8	10.8
300 - 303	2	25	282.0	28.8	9.8	10.4

## LEGEND

AHRI	-	Air–Conditioning & Refrigeration Institute
ASHRAE	-	American Society of Heating, Refrigerating
		and Air Conditioning, Inc.
IFFR	_	Integrated Energy Efficiency Ratio

- EER Integrated Energy Efficiency Ratio
- IPLV Integrated Part Load Value





Use of the AHRI Certified TM Mark indicates a manufacturer's participation in the program. For verification of certification for individual products, go to www.ahridirectory.org .



#### NOTES:

1. Rated and certified under AHRI Standard 340/360–04, as appropriate.

2. Ratings are based on:

**Cooling Standard:**  $80^{\circ}F$  ( $27^{\circ}C$ ) db,  $67^{\circ}F$  ( $19^{\circ}C$ ) wb indoor air temp and  $95^{\circ}F$  ( $35^{\circ}C$ ) db outdoor air temp.

**IEER Standard**: A measure that expresses cooling part-load EER efficiency for commercial unitary air conditioning and heat pump equipment on the basis of weighted operation at various load capacities.

3. All RGS units comply with ASHRAE 90.1 2001, 2004 Energy Standard for minimum SEER and EER requirements.

4. RGS units comply with US Energy Policy Act (2005). To evaluate code compliance requirements, refer to state and local codes or visit the following website: http://bcap-energy.org to determine if compliance with this standard pertains to your state, territory, or municipality.

### Table 3 – SOUND PERFORMANCE TABLE

						Outdoor So	ound (dB)				
MODEL RGS	COOLING STAGES	A-Wtg.	ARI 370 Rating	63	125	250	500	1000	2000	4000	8000
210 – 213	2	84.1	84	92.2	83.9	80.4	81.8	78.7	76.5	72.2	65.4
240 – 243	2	86.5	87	95.6	87.5	84.2	84.2	81.7	77.9	73.2	66.3
300 - 303	2	85.9	86	97.1	88.3	84.4	83.3	80.7	77.4	73.4	67.3

### LEGEND

dB - Decibel

#### NOTES:

1. Outdoor sound data is measured in accordance with AHRI standard 270–2008.

2. Measurements are expressed in terms of sound power. Do not compare these values to sound pressure values because sound pressure depends on specific environmental factors which normally do not match individual applications. Sound power values are independent of the environment and therefore more accurate.

3. A-weighted sound ratings filter out very high and very low frequencies, to better approximate the response of "average" human ear. A-weighted measurements are taken in accordance with AHRI standard 270–2008.

### Table 4 – HEATING RATING TABLE – NATURAL GAS & PROPANE

		AL/SS HEAT	EXCHANGER		THERMAL
MODEL RGS	HEAT SIZE	INPUT / OUTPUT STAGE 1 (MBH)	INPUT / OUTPUT STAGE 2 (MBH)	TEMP RISE (DEG F)	EFFICIENCY (%)
	LOW	176 / 142	220 / 178	15 – 55	80%
210 – 213	MED	248 / 200	310 / 251	25 – 60	81%
	HIGH	320 / 260	400 / 324	30- 65	81%
	LOW	176 / 142	220 / 178	15 – 55	80%
240 – 243	MED	248 / 200	310 / 251	20 - 60	81%
	HIGH	320 / 260	400 / 324	30- 65	81%
	LOW	176 / 142	220 / 178	10 – 55	80%
300 - 303	MED	248 / 200	310 / 251	15 – 60	81%
	HIGH	320 / 260	400 / 324	20 – 65	81%

NOTE:

Heat ratings are for natural gas heat exchangers operated at or below 2000 ft. For information on Propane or altitudes above 2000 ft (610m), see the Application Data section of this book. Accessory Propane/High Altitude kits are also available.

In the USA the input rating for altitudes above 2000 ft (610m) must be derated by 4% for each 1000 ft (305 m) above sea level. In Canada, the input rating must be derated by 10% for altitudes of 2000 ft (610 m) to 4500 ft (1372 m) above sea level.

# Table 5 – MINIMUM – MAXIMUM AIRFLOW RATINGS – NATURAL GAS & LIQUID PROPANE

MODEL		COC	LING	AL HX I	HEATING	SS HX I	IEATING
RGS	HEAT SIZE	MINIMUM	MAXIMUM	MINIMUM	MAXIMUM	MINIMUM	MAXIMUM
	LOW			2960	10860	2960	10860
210 – 213	MED	5250	9000	3880	9300	3880	9300
	HIGH			4620	10000	4620	10000
	LOW			2960	10860	2960	10860
240 – 243	MED	6000	10000	3880	11630	3880	11630
	HIGH			4620	10000	4620	10000
	LOW			2960	16300	2960	16300
300 - 303	MED	7500	12500	3880	15500	3880	15500
	HIGH			4620	15000	4620	15000

# Table 6 – PHYSICAL DATA (COOLING) 17.5 – 25 TONS

RGS	210	240	300
Refrigeration System			
# Circuits / # Comp. / Type	2 / 2 / Scroll	2 / 2 / Scroll	2 / 2 / Scroll
R-410a charge A/B (lbs)	9.5/12.0	20.6/14.7	19.8/20.4
Metering device	Fixed	Fixed	Fixed
High–press. Trip / Reset (psig)	630 / 505	630 / 505	630 / 505
Low–press. Trip / Reset (psig)	54 / 117	54 / 117	54 / 117
Compressor Capacity Staging (%)	50 / 100	50 / 100	50 / 100
	,	,	,
vap. Coil laterial	Cu / Al	Cu / Al	Cu / Al
	3/8–in	-	
ube Diameter	,	3/8-in	3/8-in
Rows / FPI	4 / 15	4 / 15	4 / 15
otal face area (ft2)	22.00	22.00	23.11
condensate drain conn. size	3/4–in	3/4–in	3/4–in
vap. fan and motor VERTICAL			
Motor Qty / Drive type	1 / Belt	1 / Belt	1 / Belt
ा स्थित दिए / Drive type	3.3	4.9	4.9
P RPM range	622-822	690-863	717–911
Motor frame size	56	56	56
Fan Qty / Type	2 / Centrifugal	2 / Centrifugal	2 / Centrifugal
о Fan Diameter (in)	15 x 15	15 x 15	15 x 15
Motor Qty / Drive type	1 / Belt	n/a	n/a
Max BHP	4.9	n/a	n/a
ស៊ី RPM range	713-879	n/a	n/a
Max BHP Max BHP Motor frame size Fan Qty / Type	56	n/a	n/a
Fan Qty / Type	2 / Centrifugal	n/a	n/a
S Fan Diameter (in)	15 x 15	n/a	n/a
		, =	,
Motor Qty / Drive type	n/a	1 / Belt	1 / Belt
T Max BHP	n/a	6.5	6.5
전 법 RPM range	n/a	835–1021	913–1116
Image  Max BHP    Image  RPM range    Image  Motor frame size    Image  Frame    Image  Frame <t< td=""><td>n/a</td><td>184T</td><td>184T</td></t<>	n/a	184T	184T
이 Max BHP 장 법 RPM range 다 전 Motor frame size 다 Fan Qty / Type	n/a	2 / Centrifugal	2 / Centrifugal
≥ Fan Diameter (in)	n/a	15 x 15	15 x 15
Motor Qty / Drive type	1 / Belt	1 / Belt	1 / Belt
은 🗶 Max BHP	6.5	8.7	8.7
이 전 Max BHP 방 표 RPM range 다 한 Motor frame size 단 표 Fan Qtv / Type	882-1078	941–1176	941–1176
ਸ਼ੁੱਤੂ ਸ਼ੁੱਤੂ Motor frame size	184T	213T	213T
플 Fan Qty / Type	2 / Centrifugal	2 / Centrifugal	2 / Centrifugal
Fan Diameter (in)	15 x 15	15 x 15	15 x 15

Section 313 of the Energy Independence and Security Act of 2007 (EISA 2007) mandates that the efficiency of general purpose motors we use in our Light Commercial Rooftops rated at 5.0 HP and larger be increased on or after December 19, 2010. We will offer both medium and standard efficient motors until inventory is depleted and then shift over solely to the high efficient motors only.


	RGS	213	243	303
HORIZONTAL				
	Motor Qty / Drive type	1 / Belt	1 / Belt	1 / Belt
atic	Max BHP	3.3	4.9	4.9
Standard Static	RPM range	622-822	690-863	647–791
ard	Motor frame size	56	56	56
pu			2 / Centrifugal	
Sta	Fan Qty / Type	2 / Centrifugal 18 x 15 & 15 X 11	18 x 15 & 15 X 11	2 / Centrifugal
	Fan Diameter (in)	18 X 15 & 15 X 11	18 X 15 & 15 X 11	18 x 15 & 15 X 11
	Motor Qty / Drive type	1 / Belt	n/a	n/a
atic	Max BHP	4.9	n/a	n/a
Medium Static	RPM range	713–879	n/a	n/a
L L L	Motor frame size	56	n/a	n/a
edi	Fan Qty / Type	2 / Centrifugal	n/a	n/a
Σ	Fan Diameter (in)	18 x 15 & 15 X 11	n/a	n/a
<u>.0</u>	Motor Qty / Drive type	n/a	1 / Belt	1 / Belt
itat	Max BHP	n/a	6.5	6.5
Medium Static High Eff*	RPM range	n/a	835–1021	755–923
	Motor frame size	n/a	184T	184T
T de	Fan Qty / Type	n/a	2 / Centrifugal	2 / Centrifugal
_	Fan Diameter (in)	n/a	18 x 15/15 x 11	18 x 15/15 x 11
[]	Motor Qty / Drive type	1 / Belt	1 / Belt	1 / Belt
	Max BHP	6.5	8.7	8.7
High Static High Eff*	RPM range	882–1078	941–1176	827–1010
P U St				
ligh Lig	Motor frame size	184T	213T	213T
I - I	Fan Qty / Type	2 / Centrifugal	2 / Centrifugal	2 / Centrifugal
	Fan Diameter (in)	18 x 15/15 x 11	18 x 15/15 x 11	18 x 15/15 x 11
ond. Coil (Circu	uit A)			
•	, Coil type	RTPF	RTPF	RTPF
	Coil Length (in)	70	82	75
	Coil Height (in)	44	44	52
	Total face area (ft2)	21.4	25.1	27.1
ond. Coil (Circu				
	Coil type	RTPF	RTPF	RTPF
	Coil Length (in)	70	57	75
	Coil Height (in)	44	44	52
	Total face area (ft2)	21.4	17.4	27.1
ond. fan / moto	r			
.,	Qty / Motor drive type	3 / direct	4 / direct	4 / direct
	Motor HP / RPM	1/4 / 1100	1/4 / 1100	1/4 / 1100
	Fan diameter (in)	22	22	22
ilters				
	RA Filter # / size (in)	6 / 20 x 25 x 2	6 / 20 x 25 x 2	9 / 16 x 25 x 2
	OA inlet screen # / size (in)	4 / 16 x 25 x 1	4 / 16 x 25 x 1	4 / 16 x 25 x 1
		+, 10 X 20 X 1	7,10,20,1	+/ 13 X 20 X 1


# Table 7 – PHYSICAL DATA (COOLING) 17.5 – 25 TONS (Cont.)

\* Section 313 of the Energy Independence and Security Act of 2007 (EISA 2007) mandates that the efficiency of general purpose motors we use in our Light Commercial Rooftops rated at 5.0 HP and larger be increased on or after December 19, 2010. We will offer both medium and standard efficient motors until inventory is depleted and then shift over solely to the high efficient motors only.

# Table 8 – PHYSICAL DATA (HEATING) 17.5 – 25 TONS

RGS	210 – 213	240 – 243	300 - 303
Gas Connection			
# of Gas Valves	1	1	1
Nat. gas supply line press (in. w.g.)/(PSIG)	5 –13 / 0.18–0.47	5 -13 / 0.18-0.47	5 –13 / 0.18–0.47
Propane supply line press (in. w.g.)/(PSIG)	11–13 / 0.40–0.47	11-13 / 0.40-0.47	11-13 / 0.40-0.47
Heat Anticipator Setting (Amps)			
1st stage	0.14	0.14	0.14
2nd stage	0.14	0.14	0.14
Natural Gas Heat			
# of stages / # of burners (total)	2/5	2/5	2/5
Connection size	3/4" NPT	3/4" NPT	3/4" NPT
Rollout switch opens / closes	195 / 115	195 / 115	195 / 115
Temperature rise range (F)	25 – 55	25 – 55	25 – 55
	20 - 00	20 - 00	20 - 00
# of stages / # of burners (total)	2/7	2/7	2/7
Connection size	3/4" NPT	3/4" NPT	3/4" NPT
Rollout switch opens / closes	195 / 115	195 / 115	195 / 115
≥ Temperature rise range (F)	30- 60	30- 60	30-60
Connection size	2/10	2/10	2/10
# of stages / # of burners (total)	3/4" NPT	3/4" NPT	3/4" NPT
# of stages / # of burners (total)    U    Rollout switch opens / closes    Tomporature rise range (E)	195 / 115	195 / 115	195 / 115
Temperature rise range (F)	35– 65	35– 65	35– 65
Liquid Propane Heat			
<pre># of stages / # of burners (total)</pre>	2/5	2/5	2/5
Connection size	3/4" NPT	3/4" NPT	3/4" NPT
Rollout switch opens / closes	195 / 115	195 / 115	195 / 115
Temperature rise range (F)	25 – 55	25 – 55	25 – 55
# of stages / # of burners (total)	2/7	2/7	2/7
Connection size	3/4" NPT	3/4" NPT	3/4" NPT
Rollout switch opens / closes	196 / 115	197 / 115	198 / 115
≥ Temperature rise range (F)	30- 60	30- 60	30– 60
# of stages / # of burners (total)	2 / 10	2/10	2/10
Connection size	2 / 10 3/4" NPT		2 / 10 3/4" NPT
エ Connection size		3/4" NPT	
	195 / 115	195 / 115	195 / 115
⊥ Temperature rise range (F)	35– 65	35– 65	35– 65







WEIGHT & DIMENSIONS – R	GS210 – 213 (cont.)
-------------------------	---------------------

LOC	DIMENSION	CONDITION
	48 in. (1219 mm) 18 in. (457 mm)	Unit disconnect is mounted on panel No disconnect, convenience outlet option
A	18 in. (457 mm) 12 in. (305 mm)	Recommended service clearance Minimum clearance
В	42 in. (1067 mm) 36 in. (914 mm) Special	Surface behind servicer is grounded (e.g., metal, masonry wall) Surface behind servicer is electrically non-conductive (eg., wood, fiberglass) Check for sources of flue products within 10 ft. of unit fresh air intake hood
С	36 in. (914 mm) 18 in. (457 mm)	Side condensate drain is used Minimum clearance
D	42 in. (1067 mm) 36 in. (914 mm)	Surface behind servicer is grounded (e.g., metal, masonry wall, another unit) Surface behind servicer is electrically non-conductive (eg., wood, fiberglass)






# BASE UNIT DIMENSIONS - RGS240/243 - 300/303



#### Unit Weight Corner Weight (D) Center of Gravity In [mm] Corner Corner Corner Weight (A) Weight (B) Weight (C) UNIT Kg 1105 Kg 253 Kg 249 Ќд 221 Ζ Lb Lb Lb Lb Kg Lb Х Y 40–1/8 [1020] 41–5/8 [1058] 16-1/2 [419] 2436 558 548 479 217 487 70 [1778] 240/243 300/303 2561 1162 571 259 564 256 528 239 534 242 70–1/4 [1784] 19 [483] Y CORNER A CORNER B Х z FRONT CORNER C CORNER D 1. TOP С × D В А T

WEIGHT & CLEARANCE DIMENSIONS – R	RGS240/243-300/303 (cont.)
-----------------------------------	----------------------------

LOC	DIMENSION	CONDITION
	48 in. (1219 mm)	Unit disconnect is mounted on panel
•	18 in. (457 mm)	No disconnect, convenience outlet option
A	18 in. (457 mm)	Recommended service clearance
	12 in. (305 mm)	Minimum clearance
	42 in. (1067 mm)	Surface behind servicer is grounded (e.g., metal, masonry wall)
В	36 in. (914 mm)	Surface behind servicer is electrically non-conductive (eg., wood, fiberglass)
	Special	Check for sources of flue products within 10 ft. of unit fresh air intake hood
с	36 in. (914 mm)	Side condensate drain is used
C	18 in. (457 mm)	Minimum clearance
D	42 in. (1067 mm)	Surface behind servicer is grounded (e.g., metal, masonry wall, another unit)
U	36 in. (914 mm)	Surface behind servicer is electrically non-conductive (eg., wood, fiberglass)



# **OPTIONS AND ACCESSORIES WEIGHT ADDERS**

BASE UNIT WITH OPTIONS AND			MAX WEI	GHT ADD		
ACCESSORIES	RGS2	10/213	RGS240/243		RGS300/303	
(Weight Adders)	lb	kg	lb	kg	lb	kg
Base Unit Operating Weight	1922	872	2072	940	2197	997
Power Exhaust	125	57	125	57	125	57
Economizer	170	77	170	77	195	88
Copper Tube/Fin Evaporator Coil	110	50	135	61	161	73
Low Gas Heat	85	39	85	39	85	39
Medium Gas Heat	90	41	90	41	90	41
High Gas Heat	113	51	113	51	113	51
Flue Discharge Deflector	7	3	7	3	7	3
Roof Curb 14–in (356mm)	240	109	240	109	255	116
Roof Curb 24–in (610mm)	340	154	340	154	355	161
Louvered Hail Guard	60	27	120	54	150	68
CO <sub>2</sub> sensor	5	2	5	2	5	2
Supply Smoke Detector	5	2	5	2	5	2
Fan/Filter Status Switch	2	1	2	1	2	1
Non-Fused Disconnect	15	7	15	7	15	7
Non–Powered Convenience Outlet	5	2	5	2	5	2
Enthalpy Sensor	2	1	2	1	2	1
Differential Enthalpy Sensor	3	1	3	1	3	1
Two Position Motorized Damper	50	23	50	23	65	29
Manual Damper	35	16	35	16	40	18
Field Filter Track 4-in (102mm)	12	5	12	5	18	8
MotorMaster Controller	35	16	35	16	35	16
Standard Static Motor/Drive	0	0	0	0	0	0
Medium Static Motor/Drive	6	3	6	3	6	3
High Static Motor/Drive	12	5	16	7	16	7
Barometric Relief Hood (Horizontal)	25	11	25	11	25	11

# **APPLICATION DATA**

## Min operating ambient temp (cooling):

In mechanical cooling mode, your rooftop unit can safely operate down to an outdoor ambient temperature of  $30^{\circ}F$  ( $-1^{\circ}C$ ). It is possible to provide cooling at lower outdoor ambient temperatures by using less outside air, economizers, and/or accessory low ambient kits.

# Max operating ambient temp (cooling):

The maximum operating ambient temperature for cooling mode is 115°F (46°C). While cooling operation above 115°F (46°C) may be possible, it could cause either a reduction in performance, reliability, or a protective action by the unit's internal safety devices.

# Min mixed air temp (heating):

Using the factory settings, the minimum temperatures for the mixed air (the combined temperature of the warm return air and the cold outdoor air) entering the dimpled, gas heat exchangers are:

Aluminized	Stainless Steel
50°F (10°C) continuous	40°F (4°C) continuous
45°F (7°C) intermittent	35°F (2°C) intermittent

Operating at lower mixed-air temperatures may be possible, if a field-supplied, outdoor air thermostat initiates both heat stages when the temperature is less than the minimum temperatures listed above. Please contact your local representative for assistance.

# Min and max airflow (heating and cooling):

To maintain safe and reliable operation of your rooftop, operate within the heating airflow limits during heating mode and cooling airflow limits during cooling mode. Operating above the max may cause blow-off, undesired airflow noise, or airflow related problems with the rooftop unit. Operating below the min may cause problems with coil freeze-up and unsafe heating operation. Heating and cooling limitations differ when evaluating operating CFM, the minimum value is the HIGHER of the cooling and heating minimum CFM values published in Table 5 and the maximum value is the LOWER of the cooling and heating minimum values published in Table 5.

# Heating-to-cooling changeover:

This unit will automatically change from heating to cooling mode when using a thermostat with an auto-change-over feature.

# Airflow:

All units are draw-though in cooling mode and blow-through in heating mode.

# Outdoor air application strategies:

Economizers reduce operating expenses and compressor run time by providing a free source of cooling and a means of ventilation to match application changing needs. In fact, they should be considered for most applications. Also, consider the various economizer control methods and their benefits, as well as sensors required to accomplish your application goals.

# Motor limits, break horsepower (BHP):

Due to internal design of units, the air path, and specially designed motors, the full horsepower (maximum continuous BHP) band can be used with the utmost confidence. There is no need for extra safety factors, as motors are designed and rigorously tested to use the entire, listed BHP range without either nuisance tripping or premature motor failure.

# Propane heating:

Propane has different physical qualities than natural gas. As a result, propane requires different fuel to air mixture. To optimize the fuel/air mixture for propane, a kit with different burner orifices in an easy to install accessory. To select the correct burner orifices or determine the heat capacity for an propane application, use either the selection software, or the unit's service manual.

# High altitude heating:

High altitudes have less oxygen, which affects the fuel/air mixture in heat exchangers. In order to maintain a proper fuel/air mixture, heat exchangers operating in altitudes above 2000 ft (610 m) require different orifices. To select the correct burner orifices or determine the heat capacity for a high altitude application, use either the selection software, or the unit's service manual.

High altitudes have less oxygen, which means heat exchangers need less fuel. The new gas orifices in this field-installed kit make the necessary adjustment for high altitude applications. They restore the optimal fuel to air mixture and maintain healthy combustion on altitudes above 2000 ft (610 m).

**NOTE**: Typical natural gas heating value ranges from 975 to 1050 Btu/ft<sup>3</sup> at sea level nationally. The heating value goes down approximately 1.7% per every thousand feet elevation. Standard factory orifices can typically be used up to 2000 ft (610m) elevation without any operational issues.

**NOTE**: For installations in Canada, the input rating should be derated by 10% for altitudes from 2000 ft (610m)to 4500 ft (1372m) above sea level.

# Sizing a rooftop

While an air conditioner needs to have enough capacity to meet the design loads, it doesn't need excess capacity. In fact, excess capacity typically results in very poor part load performance and humidity control.

Using higher design temperatures than ASHRAE recommends for your location, adding "safety factors" to the calculated load, are all signs of oversizing air conditioners. Oversizing the air conditioner leads to poor humidity control, reduced efficiency, higher utility bills, larger indoor temperature swings, excessive noise, and increased wear and tear on the air conditioner.

Rather than oversizing an air conditioner, engineers should "right-size" or even slightly undersize air conditioners. Correctly sizing an air conditioner controls humidity better; promotes efficiency; reduces utility bills; extends equipment life, and maintains even, comfortable temperatures.

# Low ambient applications

The optional economizer can adequately cool your space by bringing in fresh, cool outside air. In fact, when so equipped, accessory low-ambient kit may not be necessary. In low ambient conditions, unless the outdoor air is excessively humid or contaminated, economizer-based "free cooling" is the preferred less costly and energy conscious method.

In low ambient applications where outside air might not be desired (such as contaminated or excessively humid outdoor environments), your rooftop can operate to ambient temperatures down to  $-20^{\circ}$ F ( $-29^{\circ}$ C) using the recommended accessory Motormaster low ambient controller.

#### **Table 9 – COOLING CAPACITIES**

17.5 TONS (2 Stage Cooling)

									BIENT TE	MPERATU					
	RGS2	210/2 <sup>-</sup>	13		85			95			105			115	
	11002				EAT (DB)			AT (DB)			EAT (DB)			EAT (DB)	
				75	80	85	75	80	85	75	80	85	75	80	85
		58	THC	180.4	185.6	196.3	167.7	176.1	186.9	154.7	165.3	176.6	142.2	153.6	164.9
		50	SHC	166.5	185.6	196.3	160.6	176.1	186.9	152.7	165.3	176.6	142.2	153.6	164.9
		62	THC	196.2	195.5	196.9	183.6	182.9	187.2	169.3	168.7	176.9	153.4	154.1	165.
E	<u></u>	02	SHC	146.8	172.1	194.7	141.4	166.6	187.2	135.4	160.5	176.9	128.6	152.5	165.
	(dw)	67	THC	216.7	215.9	215.2	204.9	204.1	203.1	190.6	189.7	189.0	174.8	174.0	173.
<sup>2</sup>	EAT	07	SHC	120.0	146.1	171.8	115.4	141.5	167.1	109.8	136.1	161.7	103.8	130.2	155.
õ	Щ	72	THC	237.4	236.8	236.0	226.0	225.1	224.2	212.8	211.9	211.0	197.3	196.4	195.
		12	SHC	92.0	118.3	144.3	87.8	114.3	140.4	83.0	109.6	135.8	77.6	104.2	130.
		76	THC		252.9	253.0	—	242.5	241.6	_	229.1	228.2	-	214.1	213.
		10	SHC	-	95.1	121.4	-	91.7	118.0	-	87.3	113.8	-	82.5	107.
		58	THC	188.8	198.5	209.3	176.5	188.2	200.2	164.5	176.7	189.0	151.9	164.2	176.
		50	SHC	180.4	198.5	209.3	174.4	188.2	200.2	164.5	176.7	189.0	151.9	164.2	176.
		62	THC	205.2	204.6	209.6	191.8	191.5	200.4	176.6	177.6	189.2	159.9	164.2	176.
Ξ	<b>a</b>	62	SHC	159.9	188.7	209.6	154.2	183.0	200.4	147.9	174.8	189.2	141.0	164.2	176.
	(dw)	67	THC	225.5	224.5	223.5	213.5	212.5	211.7	199.1	198.3	197.4	182.3	181.4	180.
S	EAT (	67	SHC	128.3	158.4	187.8	123.8	154.1	183.5	118.4	148.9	178.1	112.2	142.7	171.
5	Ш	70	THC	245.6	245.3	244.6	234.7	233.6	232.6	220.9	219.9	218.8	205.5	204.4	203.
		72	SHC	95.4	125.9	155.7	91.7	122.2	152.4	86.9	117.7	148.1	81.7	112.5	143.
		70	THC	-	262.0	261.2	-	250.7	250.1	-	237.3	236.2	-	221.6	220.
		76	SHC	_	99.5	129.4	_	95.9	126.2	_	91.8	122.4	_	87.0	117.
		E 0	THC	197.4	209.8	221.3	186.1	199.1	211.7	173.8	186.9	200.1	160.3	173.5	186.
		58	SHC	196.8	209.8	221.3	186.1	199.1	211.7	173.8	186.9	200.1	160.3	173.5	186.
		~~	THC	212.7	212.4	221.5	198.4	199.8	212.0	182.3	186.9	200.3	$\begin{array}{rrrrrrrrrrrrrrrrrrrrrrrrrrrrrrrrrrrr$	187.	
=	~	62	SHC	173.4	205.1	221.5	167.4	197.4	212.0	160.8	186.8	200.3	153.4	173.8	187.
5	(dw)		THC	233.7	232.5	231.4	220.8	219.8	218.9	205.6	204.5	204.1	187.8	186.8	188.
	Ĕ	67	SHC	138.0	172.0	205.0	133.4	167.6	200.4	127.8	162.0	194.4	121.3	155.6	185.
2	EAT		THC	254.3	253.3	252.8	242.7	241.5	240.3	228.0	226.8	225.7	211.8	210.6	209.
		72	SHC	101.3	135.4	169.2	97.3	131.8	165.9	92.3	127.2	161.5	86.9	121.8	156.
		70	THC	_	270.7	269.9	_	259.0	258.1	_	245.0	243.6	-	228.5	227.
		76	SHC	_	106.1	140.0	_	102.4	136.5	_	98.2	132.7	_	93.2	127.
			THC	205.0	217.2	229.1	193.4	206.9	219.3	180.6	194.3	207.9	166.6	180.5	194.
		58	SHC	205.0	217.2	229.1	193.4	206.9	219.3	180.6	194.3	207.9	166.6	180.5	194.
			THC	216.7	217.4	229.4	202.5	207.1	219.6	185.9	194.5	208.4	168.4	180.7	194.
=	_	62	SHC	183.9	217.4	229.4	178.2	207.1	219.6	171.5	194.5	208.4	141.2	180.7	194.
5	, d M	-	THC	237.8	236.7	235.7	224.7	223.5	223.0	209.5	208.3	209.2	191.5	190.3	195.
	EAT (wb)	67	SHC	144.6	182.4	219.3	140.3	178.2	213.7	134.9	172.7	205.9	113.6	166.2	195.
0	ĒĀ	_	THC	258.6	257.5	256.5	246.8	245.7	244.3	231.8	230.5	229.2	215.3	213.9	212.
		72	SHC	103.9	141.8	179.2	100.0	138.3	176.1	95.1	133.9	172.1	89.7	128.6	142.
			THC	-	275.4	274.2	_	262.7	261.8	_	248.7	247.6	-	231.9	230.
		76	SHC	_	109.5	147.0	_	105.7	143.6	_	101.5	139.9	_	96.6	135.
			THC	211.3	223.6	235.9	199.7	213.4	225.7	186.4	200.7	214.3	172.1	186.5	200.
		58	SHC	211.3	223.6	235.9	199.7	213.4	225.7	186.4	200.7	214.3	172.1	186.5	200.
			THC	220.0	223.7	236.3	206.0	213.6	226.1	189.3	200.9	214.5	172.2	186.7	201.
-	-	62	SHC	194.0	223.7	236.3	188.5	213.6	226.1	181.3	200.9	214.5	172.2	186.7	201.
5	(dw)		THC	241.1	240.1	239.7	227.9	226.6	226.9	212.7	211.4	214.9	194.4	193.0	201
2	L C	67	SHC	151.0	192.1	230.2	146.9	188.3	225.2	141.6	182.9	214.8	135.3	176.3	201
	EAT		THC	262.2	261.0	259.7	250.0	248.8	247.7	235.0	233.5	232.1	218.1	216.6	215
	-	72	SHC	106.5	148.1	189.0	102.5	144.5	186.0	97.8	140.4	182.1	92.4	135.3	177.
			THC	-	278.9	277.4	-	266.0	264.8		251.5	250.6	-	234.7	233.
		76		_	2,0.0	L / / . T	_	200.0	204.0	_	201.0	200.0		207.7	200.

LEGEND:

\_

Do not operateCubic feet per minute (supply air) Cfm

EAT(db) - Entering air temperature (dry bulb)

EAT(wb) - Entering air temperature (wet bulb)

SHC - Sensible heat capacity

ΤС - Total capacity

 $h_{lwb} = h_{ewb} - \frac{total capacity (Btuh)}{4.5 x cfm}$ 

Where:  $h_{ewb} = Enthalpy$  of air entering evaporator coil

### Table 10 – COOLING CAPACITIES

20 TONS (2 Stage Cooling)

							1		SIENT TE	MPERATU					
	RGS2	20/24	13		85			95			105			115	
	11002		-0		EAT (DB)			EAT (DB)			EAT (DB)			EAT (DB)	
				75	80	85	75	80	85	75	80	85	75	80	85
		58	THC	213.1	217.2	228.7	199.9	207.5	219.4	184.8	195.8	208.4	169.6	182.6	195.6
		50	SHC	194.3	217.2	228.7	188.0	207.5	219.4	179.0	195.8	208.4	169.6	182.6	195.6
		62	THC	230.0	229.4	230.4	217.5	217.0	219.7	202.5	201.9	208.8	184.9	184.9	195.9
Ε	0	02	SHC	170.0	199.9	225.9	164.6	194.5	219.7	158.3	187.8	208.8	150.9	178.7	195.9
ŭ	wb	67	THC	251.5	251.1	250.6	239.4	238.7	238.1	225.4	224.7	224.0	208.8	208.2	207.4
6000 Cfm	EAT (wb)	67	SHC	137.5	168.1	198.4	132.9	163.4	193.7	127.5	158.1	188.2	121.1	151.9	181.9
00	E/	72	THC	274.0	273.8	273.5	262.3	261.7	261.0	248.2	247.4	246.6	232.2	231.3	230.5
		12	SHC	104.3	135.1	165.6	100.1	130.9	161.4	95.1	125.9	156.6	89.6	120.5	151.3
		76	THC	_	292.9	292.2	_	280.5	279.9	-	266.3	265.6	-	250.6	249.8
		70	SHC	-	108.1	138.6	-	104.1	134.9	-	99.6	130.4	_	94.6	125.5
-		-0	THC	220.8	229.7	241.7	208.4	219.7	232.2	194.3	208.1	221.0	180.1	194.2	207.9
		58	SHC	211.0	229.7	241.7	203.1	219.7	232.2	194.3	208.1	221.0	180.1	194.2	207.9
		~~~	THC	237.8	237.3	241.9	225.1	224.6	232.3	209.6	210.2	221.3	191.3	196.0	208.2
Е	•	62	SHC	183.3	217.8	241.9	178.2	212.1	232.3	171.8	203.8	221.3	164.3	196.0	208.2
7000 Cfm	(dw)	07	THC	260.0	259.2	258.5	247.2	246.4	245.7	232.7	231.9	231.7	215.8	215.0	214.3
8	EAT (	67	SHC	146.0	181.0	215.7	141.3	176.5	211.2	136.0	171.3	206.3	129.8	165.3	199.4
R	EA	70	THC	283.3	282.5	281.8	270.6	269.8	268.9	255.9	255.0	254.1	240.0	238.9	238.0
		72	SHC	107.9	143.2	178.1	103.6	139.0	174.1	98.6	134.2	169.5	93.2	129.0	164.4
			THC	_	302.3	301.6	_	289.1	288.4	_	274.4	273.6	-	257.9	256.8
		76	SHC	_	112.3	147.5	_	108.3	143.7	_	103.9	139.4	_	98.9	134.5
			THC	232.1	243.6	256.1	219.8	233.4	246.0	206.9	221.3	234.5	192.1	206.8	221.2
		58	SHC	227.5	243.6	256.1	219.8	233.4	246.0	206.9	221.3	234.5	192.1	206.8	221.2
			THC	247.8	247.1	256.4	234.7	235.5	246.2	218.7	221.1	234.7	199.5	207.0	221.4
F	_	62	SHC	199.5	236.7	256.4	194.3	229.1	246.2	187.8	221.1	234.7	179.9	207.0	221.4
8000 Ctm	(dw)		THC	270.2	269.3	268.3	257.0	256.1	255.2	242.1	241.0	240.3	224.5	223.5	223.1
8	Ē	67	SHC	157.6	197.1	235.6	152.7	192.6	231.0	147.3	187.2	225.3	141.0	181.0	215.6
80	EAT		THC	294.1	293.1	292.2	280.7	279.7	278.4	265.9	264.7	263.8	248.9	247.6	246.6
		72	SHC	114.8	154.6	193.9	110.3	150.4	190.0	105.4	145.6	185.5	99.7	140.1	180.2
		70	THC	-	313.1	312.3	-	299.3	298.2	-	283.8	282.8	_	266.7	265.4
		76	SHC	_	120.2	159.6	_	116.0	155.9	_	111.4	151.5	_	106.2	146.6
			THC	238.5	252.5	266.0	226.8	241.6	255.6	213.1	228.2	243.0	197.5	213.0	229.2
		58	SHC	238.5	252.5	266.0	226.8	241.6	255.6	213.1	228.2	243.0	197.5	213.0	229.2
			THC	253.0	254.1	266.3	238.6	241.6	255.7	221.0	228.4	243.3	201.1	213.2	229.4
۶	_	62	SHC	211.9	249.1	266.3	206.2	241.6	255.7	199.2	228.4	243.3	164.2	213.2	229.4
5	d v		THC	276.9	275.8	274.8	263.0	261.8	261.0	246.5	245.2	246.6	228.2	225.9	229.6
9000 Ctm	EAT (wb)	67	SHC	165.6	209.9	252.2	160.7	205.1	247.0	154.9	199.3	238.5	132.3	192.7	229.6
6	EA		THC	302.2	301.0	299.7	287.9	286.6	285.4	272.3	270.9	269.6	254.3	252.9	251.6
		72	SHC	118.2	162.8	206.8	113.5	158.4	202.9	108.5	153.4	198.0	102.7	147.8	165.1
			THC	-	322.0	320.8	_	307.7	306.1	_	291.4	289.9	-	275.1	272.5
		76	SHC	_	124.5	168.7	_	120.4	164.9	_	115.6	160.5	_	110.9	155.3
			THC	245.7	259.8	273.9	233.8	248.7	263.2	219.8	235.3	250.5	203.7	219.8	236.5
		58	SHC	245.7	259.8	273.9	233.8	248.7	263.2	219.8	235.3	250.5	203.7	219.8	236.5
			THC	256.8	260.7	274.2	242.2	249.0	263.3	224.6	235.6	250.6	205.6	220.0	236.8
E		62	SHC	223.8	258.4	274.2	218.1	249.0	263.3	211.0	235.6	250.6	199.3	220.0	236.8
5	(dv		THC	280.8	279.6	266.3	266.6	265.4	265.8	249.9	248.6	251.0	231.4	229.8	237.3
10,000 Ctm	EAT (wb)	67	SHC	173.2	221.8	266.3	168.3	217.0	258.7	162.6	211.4	250.7	156.4	204.7	237.3
0	EA.		THC	306.4	305.0	274.8	292.1	290.6	289.3	276.0	274.3	273.0	257.5	256.0	254.6
-	-	72	SHC	121.2	170.1	252.2	116.6	165.9	214.8	111.5	161.0	210.0	105.7	155.4	204.5
			THC	-	326.2	299.7	-	311.4	310.0	-	295.2	293.2	-	277.0	275.3

LEGEND:

\_

Do not operateCubic feet per minute (supply air) Cfm

EAT(db) - Entering air temperature (dry bulb)

EAT(wb) - Entering air temperature (wet bulb)

SHC - Sensible heat capacity

ΤС - Total capacity

 $h_{lwb} = h_{ewb} - \frac{total capacity (Btuh)}{4.5 \times 5^{10}}$ 

 $h_{lwb} = h_{ewb} - \frac{1}{4.5 \text{ x cfm}}$ Where:  $h_{ewb} = \text{Enthalpy of air entering evaporator coil}$ 

### Table 11 – COOLING CAPACITIES

25 TONS (2 Stage Cooling)

									BIENT TE	MPERATU					
	BUGG	300/30	13		85			95			105			115	
	nusa	500/30	5	E	EAT (DB)		E	EAT (DB)		E	EAT (DB)		E	EAT (DB)	
				75	80	85	75	80	85	75	80	85	75	80	85
		58	THC	257.3	266.5	279.6	247.5	255.4	269.0	231.5	243.3	257.2	214.3	229.2	243.
		50	SHC	247.5	266.5	279.6	231.1	255.4	269.0	223.5	243.3	257.2	EAT (DB) 75 80	243.	
		62	THC	281.4	280.5	280.6	267.5	267.0	269.3	251.3	251.0	257.6	232.7	232.5	244.
Ξ	•	62	SHC	208.2	244.0	278.0	202.3	238.4	269.3	195.8	231.5	257.6	188.1	223.4	244.
	(qw)	07	THC	307.4	306.4	305.7	293.0	292.2	291.4	276.9	276.2	275.4	259.7	259.2	258.
2	EAT (	67	SHC	168.7	205.7	242.3	163.2	200.3	236.9	157.1	194.4	230.7	150.6	188.4	224.
	Ш	72	THC	333.9	333.2	332.5	320.1	319.3	318.6	304.5	303.7	302.7	287.2	285.3	284.
		72	SHC	128.1	165.4	202.3	123.1	160.6	197.8	117.6	155.1	192.5	111.5	149.0	186.
		70	THC	-	356.0	355.2	-	342.0	341.2	-	326.0	325.2	-	308.0	307.
		76	SHC	_	132.7	169.9	_	128.1	165.6	_	123.0	160.7	_	117.3	154.
			THC	269.8	280.2	294.4	255.3	268.9	283.2	241.1	256.1	270.7	225.5	241.3	257.
		58	SHC	257.9	280.2	294.4	250.4	268.9	283.2	241.1	256.1	270.7	225.5	241.3	257.
			THC	289.9	289.3	294.6	275.3	274.9	283.6	258.7	258.2	271.0	238.8	241.6	257.
=	(	62	SHC	224.2	265.0	294.6	218.6	258.6	283.6	212.0	251.7	271.0	203.9	241.6	257.
	(dw)	07	THC	316.2	315.7	314.5	301.7	300.8	299.8	285.1	284.2	283.4			265
8	Ē	67	SHC	179.0	221.6	263.1	173.5	216.4	257.9	167.5	210.5	251.9			245
5	EAT		THC	343.7	342.7	341.6	315.3	327.9	327.0	313.1	311.4	310.4	294.3	293.2	292
		72	SHC	132.4	175.4	217.7	127.6	170.7	213.3	122.0	165.3	208.3	115.6		202
			THC	_	366.0	364.9	_	351.2	350.1	_	334.2	333.2			314
		76	SHC	_	138.0	180.7	_	133.4	176.5	_	128.2	171.6	_		166
			THC	277.1	291.8	306.8	264.9	280.2	295.3	251.2	267.0	282.3			268
		58	SHC	275.3	291.8	306.8	264.9	280.2	295.3	251.2	267.0	282.3			268
			THC	296.8	296.0	307.2	281.8	281.8	295.6	264.7	267.1	282.6			268
	-	62	SHC	239.8	283.9	307.2	234.0	276.8	295.6	227.5	267.1	282.6			268
	(dw)		THC	323.5	322.6	321.4	308.5	307.4	306.5	291.3	290.2	289.3			270
	ι Σ	67	SHC	188.8	236.9	282.9	183.5	231.9	277.4	177.5	226.1	271.2			264
5	EAT		THC	351.8	350.5	349.2	336.6	335.4	334.1	319.7	318.3	317.1			297
		72	SHC	136.6	185.1	232.8	131.6	180.4	228.6	126.0	175.1	223.7			217
			THC	_	374.2	372.8	-	358.6	357.3	-	340.9	339.7			320
		76	SHC	_	143.1	191.2	_	138.5	187.1	_	133.3	182.3			176
			THC	285.8	301.5	317.0	273.8	289.0	305.1	259.8	276.1	291.7			277
		58	SHC	285.8	301.5	317.0	273.8	289.0	305.1	259.8	276.1	291.7			277
			THC	302.2	302.3	317.4	286.3	289.5	305.4	269.6	276.4	208.4			277
		62	SHC	254.3	302.3	317.4	245.8	289.5 289.5	305.4	203.0	276.4	208.4			277
)	(dw)		THC	328.7	327.7	326.7	313.5	312.2	311.1	296.0	294.8	294.3			277
	2	67	SHC	197.9	251.1	301.0	192.8	246.4	295.4	187.0	294.0 240.4	288.0			277
	EAT		THC	357.4	355.9	354.4	341.8	340.3	339.0	324.4	322.8	321.6			302
	ш	72	SHC	140.2	193.9	246.7	135.2	189.4	242.8	129.7	184.3	238.2			198
															324
		76	THC	_	379.7	378.2	-	363.9	362.3	—	345.7	344.2			
			SHC	-	147.6	200.8	-	143.1	196.9	-	138.0	192.3			187
		58	THC	293.7	309.8	325.6	280.3	297.3	313.5	267.0	283.5	299.8			284
			SHC	293.7	309.8	325.6	280.3	297.3	313.5	267.0	283.5	299.8			284
		62	THC	310.5	310.2	326.1	290.7	297.6	313.9	273.7	283.7	300.1	253.1	268.5	285
	(q		SHC	264.9	310.1	326.1	262.1	297.6	313.9	255.7	283.7	300.1	246.9	268.5	285
	3	67	THC	333.1	331.7	330.9	317.5	316.2	315.9	299.8	298.7	300.3	280.7	279.6	285
	EAT (wb)		SHC	206.6	264.7	317.6	201.9	260.2	311.0	196.2	254.9	300.3	190.0	248.1	285
	ш	72	THC	362.1	360.3	358.7	346.0	344.3	343.0	328.2	326.6	325.1	308.4	306.6	305
			SHC	143.6	202.4	260.2	138.7	198.1	256.5	133.2	193.2	252.1	127.1	187.5	246
		76	THC	-	384.3	382.5	-	368.1	366.3	—	349.5	347.8	-	331.0	328
	1		SHC	-	151.9	210.1	-	147.5	206.4	—	142.5	201.9	-	137.4	195

### LEGEND:

\_

Do not operateCubic feet per minute (supply air) Cfm

EAT(db) - Entering air temperature (dry bulb)

EAT(wb) - Entering air temperature (wet bulb)

SHC - Sensible heat capacity

ΤС - Total capacity

 $h_{lwb} = h_{ewb} - \frac{total capacity (Btuh)}{4.5 x cfm}$ 

Where:  $h_{ewb} = Enthalpy$  of air entering evaporator coil

### Economizer - Vertical and Horizontal Duct Configuration

	Model Sizes 210 – 303												
CFM	4500	5000	5500	6000	6500	7000	7500	8000					
Vertical & Horizontal	0.047	0.052	0.057	0.062	0.067	0.072	0.077	0.082					

	Model Sizes 210 – 303												
CFM	8500	9000	9500	10000	10500	11000	11500	12000	12500				
Vertical & Horizontal	0.088	0.093	0.098	0.103	0.109	0.114	0.119	0.125	0.131				

#### General fan performance notes:

- 1. Interpolation is permissible. Do not extrapolate.
- 2. External static pressure is the static pressure difference between the return duct and the supply duct plus the static pressure caused by any FIOPs or accessories.
- 3. Tabular data accounts for pressure loss due to clean filters, high gas heat, unit casing, and wet coils. Factory options and accessories may add static pressure losses, as shown in Table 12.
- 4. The Fan Performance tables offer motor/drive recommendations. In cases when two motor/drive combinations would work, the lower horsepower option is recommended.
- 5. For information on the electrical properties of motors, please see the Electrical information section of this book.
- 6. For more information on the performance limits of motors, see the application data section of this book.

# **FAN PERFORMANCE**

# Table 13 - RGS210, 17.5 TON

## **VERTICAL SUPPLY / RETURN**

				Availabl	e External St	atic Pressure	e (in. wg)							
CFM	0	.2	0.	.4	0	.6	0	.8	1.	.0				
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP				
5250	541	1.08	618	1.42	688	1.79	754	2.19	817	2.62				
5700	573	1.31	645	1.67	712	2.06	775	2.48	835	2.93				
6100	602	1.55	670	1.93	734	2.34	795	2.77	852	3.23				
6500	631	1.81	696	2.21	757	2.64	815	3.09	871	3.57				
7000	668	2.19	729	2.61	787	3.06	843	3.53	896	4.03				
7500	706	2.62	763	3.06	819	3.54	871	4.03	922	4.55				
7900	736	3.00	791	3.47	844	3.96	895	4.47	944	5.00				
8300	767	3.42	819	3.90	870	4.41	919	4.94	967	5.49				
8750	801	3.94	852	4.44	900	4.97	948	5.52	993	6.09				
	Available External Static Pressure (in. wg)													
CFM	1.	.2	1.	.4	1	.6	1	.8	2	.0				
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP				
5250	876	3.08	932	3.56	986	4.07	1038	4.60	1088	5.15				
5700	892	3.40	946	3.90	998	4.42	1049	4.96	1097	5.52				
6100	907	3.72	960	4.23	1011	4.76	1060	5.31	1107	5.89				
6500	924	4.07	975	4.59	1025	5.13	1072	5.70	1119	6.28				
7000	947	4.55	996	5.09	1044	5.65	1090	6.23						
7500	971	5.08	1019	5.64	1064	6.22								
7900	992	5.55	1038	6.13										
8300	1013	6.06			]									
8750														

Std Static Motor and Drive - 622-822 RPM, Max BHP 3.3 High Static Motor and Drive - 882-1078 RPM, Max BHP 6.5 Medium Static Motor and Drive - 713-879 RPM, Max BHP 4.9 ---- Outside operating range

Boldface - Field-supplied Drive

### Table 14 – RGS240, 20 TON

### **VERTICAL SUPPLY / RETURN**

				Availabl	e External St	atic Pressure	e (in. wg)				
CFM	0.	2	0.	.4	0	.6	0.	.8	1.	0	
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	
6000	605	1.48	674	1.77	738	2.08	798	2.41	854	2.74	
6500	644	1.82	709	2.14	770	2.47	827	2.81	881	3.17	
7000	683	2.22	744	2.56	802	2.91	857	3.28	908	3.65	
7500	722	2.68	781	3.04	836	3.41	888	3.80	938	4.19	
8000	762	3.20	818	3.58	870	3.97	920	4.38	968	4.79	
8500	803	3.78	855	4.19	905	4.60	953	5.02	999	5.46	
9000	843	4.43	893	4.86	941	5.30	987	5.74	1032	6.19	
9500	884	5.15	932	5.61	978	6.06	1022	6.53	1065	7.01	
10000	925	5.95	970	6.43	1015	6.91	1057	7.40	1098	7.89	
				Availabl	e External St	atic Pressure	e (in. wg)				
CFM	1.	2	1.	.4	1	.6	1.	8	2.	0	
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	
6000	907	3.10	958	3.46	1006	3.84	1052	4.23	1097	4.63	
6500	932	3.54	981	3.92	1027	4.31	1073	4.72	1116	5.14	
7000	958	4.04	1005	4.43	1051	4.84	1094	5.27	1137	5.70	
7500	985	4.59	1031	5.01	1075	5.44	1118	5.87	1159	6.32	
8000	1014	5.21	1058	5.65	1101	6.09	1142	6.55			
8500	1044	5.90	1087	6.35	1128	6.82	1168	7.29			
9000	1075	6.66	1116	7.13	1156	7.61					
9500	1106	7.49	1146	7.98							
10000	1139	8.40									
Std Static M	otor and Drive	e – 690–863 I	RPM, Max BHI	P 4.9	Medium Static Motor and Drive – 835–1021 RPM, Max BHP 6.5						
High Static N	Motor and Driv	ve – 941–117	'6 RPM, Max E	BHP 8.7	Outside operating range						

### Table 15 - RGS300, 25 TON

### **VERTICAL SUPPLY / RETURN**

					le External Sta							
CFM	0.		0	.4	0.	.6	0	.8	1.	-		
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP		
7500	713	2.25	778	2.61	838	2.97	894	3.36	946	3.76		
8000	752	2.68	814	3.06	871	3.44	925	3.85	976	4.26		
8500	791	3.17	850	3.56	905	3.97	957	4.39	1006	4.83		
9000	831	3.71	887	4.12	939	4.55	989	4.99	1037	5.45		
9500	870	4.31	924	4.75	974	5.19	1023	5.66	1069	6.13		
10000	910	4.83	961	5.43	1010	5.90	1057	6.38	1102	6.87		
10500	950	5.70	999	6.18	1046	6.67	1091	7.17	1135	7.69		
11000	990	6.50	1037	7.01	1083	7.52	1126	8.04	1168	8.57		
11500	1030	7.38	1076	7.90	1119	8.43						
12000	1070	8.33										
12500												
				Availab	le External Sta	atic Pressure	e (in. wg)					
CFM	1.	2	1	.4	1.	.6	1	.8	1.	0		
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP		
7500	996	4.17	1044	4.60	1089	5.05	1133	5.51	1175	5.98		
8000	1024	4.70	1071	5.14	1115	5.60	1158	6.07				
8500	1053	5.27	1098	5.74	1141	6.21						
9000	1083	5.91	1127	6.39	1169	6.88						
9500	1113	6.61	1156	7.11								
10000	1145	7.38										
10500												
11000												
11500												
12000												
12500												
d Static M	otor and Drive	- 717-911	RPM, Max BH	P 4.9	Medium Sta	tic Motor and	Drive - 913-	-1116 RPM, M	ax BHP 6.5			
	Matar and Driv	ve – 941–117			Medium Static Motor and Drive – 913–1116 RPM, Max BHP 6.5							

### Table 16 - RGS213, 17.5 TON

## **HORIZONTAL SUPPLY / RETURN**

				Availab	le External St	atic Pressure	(in. wg)			
CFM	0.	.2	0	.4	0	.6	0	.8	1.	.0
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP
5250	587	1.62	650	2.11	708	2.63	761	3.18	811	3.77
5700	626	1.98	686	2.51	740	3.05	791	3.63	840	4.25
6100	661	2.35	718	2.91	771	3.48	820	4.09	866	4.73
6500	696	2.76	751	3.36	802	3.96	849	4.59	894	5.25
7000	741	3.34	793	3.99	841	4.63	886	5.30	929	5.99
7500	786	4.01	836	4.70	882	5.39	925	6.09		
7900	823	4.60	871	5.34	915	6.06				
8300	860	5.26	906	6.03						
8750	901	6.06								
				Availab	le External St	atic Pressure	(in. wg)			
CFM	1.	.2	1	.4	1	.6	1.	.8	2.	.0
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP
	111 191									
5250	858	4.40	902	5.05	943	5.72	983	6.41		
5250 5700								6.41		
	858	4.40	902	5.05	943	5.72		6.41	 	 
5700	858 885	4.40 4.90	902 928	5.05 5.58	943	5.72		6.41 	 	 
5700 6100	858 885 911	4.40 4.90 5.40	902 928	5.05 5.58	943	5.72		6.41  	 	
5700 6100 6500	858 885 911	4.40 4.90 5.40	902 928	5.05 5.58	943	5.72		6.41  	  	
5700 6100 6500 7000	858 885 911	4.40 4.90 5.40	902 928	5.05 5.58	943	5.72		6.41   	   	  
5700 6100 6500 7000 7500	858 885 911	4.40 4.90 5.40	902 928	5.05 5.58	943	5.72		6.41   	   	
5700 6100 6500 7000 7500 7900	858 885 911	4.40 4.90 5.40	902 928	5.05 5.58	943	5.72		6.41   	    	
5700 6100 6500 7000 7500 7900 8300 8750	858 885 911	4.40 4.90 5.40 5.94 	902 928 953  	5.05 5.58 6.10  	943 969     	5.72 6.28   		   		

Boldface - Field-supplied Drive

### Table 17 - RGS243, 20 TON

HORIZONTAL SUPPLY / RETURN

				Availab	le External St	atic Pressure	e (in. wg)					
CFM	0.	2	0	.4	0	.6	0	.8	1.	0		
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP		
6000	651	2.25	709	2.78	762	3.35	812	3.96	858	4.60		
6500	696	2.77	750	3.33	801	3.94	848	4.57	893	5.24		
7000	741	3.37	792	3.96	840	4.60	886	5.27	929	5.97		
7500	787	4.05	834	4.67	880	5.34	924	6.05	965	6.78		
8000	833	4.83	878	5.48	921	6.18	963	6.92	1003	7.69		
8500	879	5.70	922	6.39	963	7.13	1003	7.89	1042	8.69		
9000	926	6.69	966	7.41	1006	8.17						
9500	973	7.78	1011	8.54								
10000												
			e (in. wg)									
CFM	1.	2	1	.4	1	.6	1	.8	2.	0		
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP		
6000	902	5.25	943	5.93	983	6.62	1021	7.32	1057	8.04		
6500	935	5.94	976	6.65	1014	7.38	1051	8.12	1086	8.88		
7000	970	6.70	1009	7.44	1046	8.21						
7500	1005	7.54	1043	8.32								
8000	1042	8.48										
8500												
9000												
9500												
10000												
Std Static M	otor and Drive	- 690-863	RPM, Max BH	P 4.9	Medium Static Motor and Drive – 835–1021 RPM, Max BHP 6.5							
ligh Static I	Motor and Driv	ve – 941–117	76 RPM, Max B	BHP 8.7	Outside operating range							

Table 18 - RGS303, 25 TON

# HORIZONTAL SUPPLY / RETURN

				Availab	e External St	atic Pressure	e (in. wg)			
CFM	0	.2	0	.4	0	.6	0	.8	1.	.0
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP
7500	715	3.12	767	3.68	815	4.28	862	4.90	906	5.58
8000	751	3.65	800	4.25	847	4.87	892	5.53	934	6.21
8500	786	4.24	834	4.86	879	5.51	922	6.19	963	6.90
9000	822	4.88	867	5.53	910	6.21	952	6.91	991	7.64
9500	856	5.57	916	6.25	941	6.95	981	7.68	1020	8.44
10000	890	6.33	932	7.03	973	7.76	1011	8.52		
10500	924	7.14	965	7.87	1004	8.62				
11000	958	8.01	997	8.70						
11500	991	8.94	1029	9.73						
	Available External Static Pressure (in. wg)									
CFM	1	.2	1	.4	1	.6	1	.8	2.	.0
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP
7500	948	6.27	988	6.98	1027	7.72	1065	8.49		
8000	975	6.93	1014	7.67	1052	8.43				
8500	1002	7.64	1041	8.40						
9000	1030	8.41								
9500										
10000										
10500										
11000										
11500										
td Static M	otor and Drive	e – 647–791	RPM, Max BH	P 4.9	Medium Sta	tic Motor and	Drive - 755-	-923 RPM, Ma	x BHP 6.5	
ligh Static I	Motor and Driv	ve – 827–101	O RPM Max	BHP 8 7	Out	side operating	a rango			

# Table 19 – PULLEY ADJUSTMENT

Unit		Initial      819      798      776      755      733      712      690      669      647      6        ic      958      939      920      901      882      863      843      824      805      7        1134      1112      1090      1069      1047      1025      1003      981      960      9        tic      819      798      776      755      733      712      690      669      647      6										
RGS	Motor/Drive Combo	0.0	0.5	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5	5.0
	Standard Static	819	798	776	755	733	712	690	669	647	626	604
210 – 213	Medium Static	958	939	920	901	882	863	843	824	805	786	767
	High Static	1134	1112	1090	1069	1047	1025	1003	981	960	938	916
	Standard Static	819	798	776	755	733	712	690	669	647	626	604
240 - 243	Medium Static	1008	989	969	950	930	911	892	872	853	833	814
	High Static	1170	1150	1129	1109	1088	1068	1047	1027	1006	986	965
	Standard Static	819	805	790	776	762	748	733	719	705	690	676
300 - 303	Medium Static	1134	1112	1090	1069	1047	1025	1003	981	960	938	916
	High Static	1293	1273	1252	1232	1211	1191	1170	1150	1129	1109	1088

**NOTE**: Do not adjust pulley further than 5 turns open.

- Factory settings

# DAMPER, BAROMETRIC RELIEF, AND PERFORMANCE, 15 to 25 Ton









Fig 2 – Barametric Relief Flow Capacity



		Voltage		Comp 1		Comp 2		OFM (ea)		IFM			
Unit RGS	V-Ph-Hz	Range MIN MAX		RLA LRA		RLA LRA		WATTS FLA		TYPE	Full Load Efficiency	FLA	
	208-3-60		253	29.5		30.1	225	350	1.5	STD	83.8%	10.2	
		187			195					MED	83.6%	15.0	
										HIGH–High Eff	89.5%	20.4	
	230-3-60	187	253	29.5	195	30.1	225	350	1.5	STD	83.8%	10.2	
										MED	83.6%	15.0	
210/213										HIGH–High Eff	89.5%	20.4	
210/213	460-3-60	414	506	14.7	95	16.7	114	277	0.9	STD	83.8%	4.8	
										MED	83.6%	7.4	
										HIGH–High Eff	89.5%	20.4	
	575-3-60	518	633	12.2	80	12.2	80	397	0.6	STD	81.1%	2.8	
										MED	83.6%	5.6	
										HIGH–High Eff	89.5%	9.0	
	208-3-60	187	253	48.1	245	29.5	195	350	1.5	STD	83.6%	15.0	
										MED-High Eff	89.5%	20.4	
										HIGH-High Eff	91.7%	33.1	
	230-3-60	187	253	48.1	245	29.5	195	350	1.5	STD	83.6%	15.0	
										MED-High Eff	89.5%	20.4	
240/243										HIGH-High Eff	91.7%	33.1	
240/243	460-3-60	414	506	18.6	125	14.7	95	277	0.9	STD	83.6%	7.4	
										MED-High Eff	89.5%	20.4	
										HIGH-High Eff	91.7%	33.1	
	575-3-60	518	633	14.7	100	12.2	80	397	0.6	STD	83.6%	5.6	
										MED-High Eff	89.5%	9.0	
										HIGH-High Eff	91.7%	9.5	
	208-3-60	187	253	48.1	245	48.1	245	350	1.5	STD	83.6%	15.0	
										MED-High Eff	89.5%	20.4	
										HIGH-High Eff	91.7%	33.1	
	230-3-60	187	253	48.1	245	48.1	245	350	1.5	STD	83.6%	15.0	
										MED–High Eff	89.5%	20.4	
000/000										HIGH-High Eff	91.7%	33.1	
300/303	460-3-60	414	506	18.6	125	18.6	125	277	0.9	STD	83.6%	7.4	
										MED-High Eff	89.5%	20.4	
										HIGH-High Eff	91.7%	33.1	
		518	633	14.7	100	14.7	100	397	0.6	STD	83.6%	5.6	
	575-3-60									MED-High Eff	89.5%	9.0	
										HIGH-High Eff	91.7%	9.5	

# Table 20 - ELECTRICAL INFORMATION

Unit RGS	NOM. V—Ph—Hz	IFM TYPE	Combustion Fan Motor FLA	Power Exhaust FLA	NO C.O. or UNPWR C.O.							
					NO P.E.				w/ P.E. (pwrd fr/ unit)			
					MCA	MOCP	DISC	DISC. SIZE		MOCP	DISC. SIZ	
210/213	208/230-3-60	STD	0.52	5.9	81.8	100	85	502	93.6	110	99	522
		MED			86.6	100	91	511	98.4	125	105	531
		HIGH—High Eff			92.0	100	97	521	103.8	125.0	111	541
	460-3-60	STD	0.3	3.1	43.1	50	45	252	49.3	60	52	264
		MED			45.7	60	48	256	51.9	60	55	268
		HIGH—High Eff			48.5	60	51	261	54.7	60	58	273
	575-3-60	STD	0.24	2.4	32.1	40	33	188	36.9	45	39	196
		MED			34.9	45	37	202	39.7	50	42	210
		HIGH-High Eff			38.3	50	40	200	43.1	50	46	208
240/243	208/230-3-60	STD	0.52	5.9	110.6	150	113	534	122.4	150	127	554
		MED—High Eff			116.0	150	120	544	127.8	175	133	564
		HIGH—High Eff			128.7	175	134	618	140.5	175	148	638
	460-3-60	STD	0.3	3.1	49.0	60	51	269	55.2	60	58	281
		MED—High Eff			51.8	60	54	274	58.0	70	61	286
		HIGH—High Eff			57.8	70	61	311	64.0	80	68	323
	575-3-60	STD	0.24	2.4	38.6	50	40	224	43.4	50	46	232
		MED—High Eff			42.0	50	44	222	46.8	60	50	230
		HIGH—High Eff			42.5	50	45	249	47.3	60	50	257
300/303	208/230-3-60	STD	0.52	5.9	129.2	175	135	584	141.0	175	148	604
		MED—High Eff			134.6	175	141	594	146.4	175	155	614
		HIGH—High Eff			147.3	175	156	668	159.1	200	169	688
	460-3-60	STD	0.3	3.1	52.9	60	55	299	59.1	70	63	311
		MED—High Eff			55.7	70	59	304	61.9	80	66	316
		HIGH—High Eff			61.7	80	66	341	67.9	80	73	353
		STD			41.1	50	43	244	45.9	60	49	252
	575-3-60	MED—High Eff	0.24	2.4	44.5	50	47	242	49.3	60	52	250
		HIGH-High Eff	1		45.0	50	47	269	49.8	60	53	277

# Table 21 – MCA/MOCP DETERMINATION NO C.O. OR UNPWRD C.O.

LEGEND: C.O. DISC

FLA

IFM

LRA

MCA

MOCP

Convenient outlet Disconnect

Full load amps

Indoor fan motor

Locked rotor amps

Minimum circuit amps

\_ Maximum over current protection Power exhaust

P.E. \_

UNPWRD CO Unpowered convenient outlet \_

NOTES:

1. IN COMPLIANCE WITH NEC REQUIREMENTS FOR MULTIMOTOR AND COMBINATION LOAD EQUIPMENT (REFER TO NEC ARTICLES 430 AND 440), THE OVERCURRENT PROTECTIVE DEVICE FOR THE UNIT SHALL BE FUSE OR HACR BREAKER. CANADIAN UNITS MAY BE FUSE OR CIRCUIT BREAKER.

#### 2. UNBALANCED 3-PHASE SUPPLY VOLTAGE

NEVER OPERATE A MOTOR WHERE A PHASE IMBALANCE IN SUPPLY VOLTAGE IS GREATER THAN 2%. USE THE FOLLOWING FORMULA TO DETERMINE THE PERCENTAGE OF VOLTAGE IMBALANCE.

max voltage deviation from average voltage % Voltage Imbalance = 100 x average voltage

Example: Supply voltage is 230-3-60

$$AB = 224 v$$
$$BC = 231 v$$
$$AC = 226 v$$

v v

Average Voltage = 
$$\frac{(224 + 231 + 226)}{3} = \frac{681}{3}$$

227

Determine maximum deviation from average voltage.

(AB) 227 – 224 = 3 v

(BC) 231 – 227 = 4 v (AC) 227 - 226 = 1 v

Maximum deviation is 4 v.

Determine percent of voltage imbalance.

% Voltage Imbalance = 
$$100 \times \frac{4}{227}$$
  
= 1.76%

This amount of phase imbalance is satisfactory as it is below the maximum allowable 2%.

IMPORTANT: If the supply voltage phase imbalance is more than 2%, contact your local electric utility company immediately.




Fig. 4 Typical Power Diagram (2 Stage Cooling)




Fig. 5 Typical Control Diagram (2 Stage Cooling)

# **SEQUENCE OF OPERATION**

# General

The sequence below describes the sequence of operation for an electro-mechanical unit with and without a factory installed "economizer". For information regarding a direct digital controller, see the start-up, operations, and troubleshooting manual for the applicable controller.

## Units with no economizer

## Cooling —

When the field supplied commercial grade thermostat calls for cooling, terminals G and Y1 are energized. As a result, the indoor-fan contactor (IFC) and the compressor contactor (C1) are energized, causing the indoor-an motor (IFM), compressor #1, and outdoor fan to start. If the unit has 2 stages of cooling, the thermostat will additionally energize Y2. The Y2 signal will energize compressor contactor #2 (C2), causing compressor #2 to start. Regardless of the number of stages, the outdoor-fan motor runs continuously while unit is cooling.

### Heating —

NOTE: Units have 2 stages of gas heat.

When the field supplied commercial grade thermostat calls for heating, power is sent to W on the Integrated Gas Controller (IGC) board. An LED (light-emitting diode) on the IGC board turns on and remains on during normal operation. A check is made to ensure that the rollout switch and limit switch are closed. If the check was successful, the induced-draft motor is energized, and when its speed is satisfactory, as proven by the "hall effect" sensor, the ignition activation period begins. The burners will ignite within 5 seconds. If the burners do not light, there is a 22-second delay before another 5-second attempt. This sequence is repeated for 15 minutes or until the burners light. If, after the 15 minutes, the burners still have not lit, heating is locked out. To reset the control, break 24-v power to the thermostat.

When ignition occurs, the IGC board will continue to monitor the condition of the rollout switch, the limit switches, the "hall effect" sensor, as well as the flame sensor. 45 seconds after ignition occurs, assuming the unit is controlled through a room thermostat set for fan auto, the indoor-fan motor will energize (and the outdoor-air dampers will open to their minimum position). If, for some reason, the over-temperature limit opens prior to the start of the indoor fan blower, the unit will shorten the 45-second delay to 5 seconds less than the time from initiation of heat to when the limit tripped. Gas will not be interrupted to the burners and heating will continue. Once the fan-on delay has been modified, it will not change back to 45 seconds until power is reset to the control.

On units with 2 stages of heat, when additional heat is required, W2 closes and initiates power to the second stage of the main gas valve. When the thermostat is satisfied, W1 and W2 open and the gas valve closes, interrupting the flow of gas to the main burners.

If the call for W1 lasted less than 1 minute, the heating cycle will not terminate until 1 minute after W1 became active. If the unit is controlled through a room thermostat set for fan auto, the indoor-fan motor will continue to operate for an additional 45 seconds then stop. If the over-temperature limit opens after the indoor motor is stopped, but within 10 minutes of W1 becoming inactive, on the next cycle the time will be extended by 15 seconds. The maximum delay is 3 minutes. Once modified, the fan off delay will not change back to 45 seconds unless power is reset to the control. A LED indicator is provided on the IGC to monitor operation.

# Units with an Economizer

### Cooling —

When free cooling is not available, the compressors will be controlled by the zone thermostat. When free cooling is available, the outdoor-air damper is modulated by the economizer control to provide a 50°F (10°C) to 55°F (13°C) mixed-air temperature into the zone. As the mixed air temperature fluctuates above 55°F (13°C)or below 50°F (10°C) dampers will be modulated (open or close) to bring the mixed-air temperature back within control. If mechanical cooling is utilized with free cooling, the outdoor-air damper will maintain its current position at the time the compressor is started. If the increase in cooling capacity causes the mixed-air temperature to drop below 45°F (7°C), then the outdoor-air damper position will be decreased to the minimum position. If the mixed-air temperature continues to fall, the outdoor-air damper will close. Control returns to normal once the mixed-air temperature rises above 48°F (9°C). The power exhaust fans will be energized and de-energized, if installed, as the outdoor-air damper opens and closes.

If field-installed accessory  $CO_2$  sensors are connected to the economizer control, a demand controlled ventilation strategy will begin to operate. As the  $CO_2$  level in the zone increases above the  $CO_2$  setpoint, the minimum position of the damper will be increased proportionally. As the  $CO_2$  level decreases because of the increase in fresh air, the outdoor-air damper will be proportionally closed. For economizer operation, there must be a thermostat call for the fan (G). If the unit is occupied and the fan is on, the damper will be closed.

When the economizer control is in the occupied mode and a call for cooling exists (Y1 on the thermostat), the control will first check for indoor fan operation. If the fan is not on, then cooling will not be activated. If the fan is on, then the control will open the economizer damper to the minimum position.

On the initial power to the economizer control, it will take the damper up to 2 1/2 minutes before it begins to position itself. After the initial power-up, further changes in damper position can take up to 30 seconds to initiate. Damper movement from full closed to full open (or vice versa) will take between 1 1/2 and 2 1/2 minutes. If free cooling can be used as determined from the appropriate changeover command (switch, dry bulb, enthalpy curve, differential dry bulb, or differential enthalpy), then the control will modulate the dampers open to maintain the mixed-air temperature setpoint at  $50^{\circ}F$  ( $10^{\circ}C$ ) to  $55^{\circ}F$  ( $13^{\circ}C$ ). If there is a further demand for cooling (cooling second stage – Y2 is energized), then the control will bring on compressor stage 1 to maintain the mixed-air temperature setpoint. The economizer damper will be open at maximum position.

### Heating —

The sequence of operation for the heating is the same as a unit with no economizer. The only difference is how the economizer acts. The economizer will stay at the Economizer Minimum Position while the evaporator fan is operating. The outdoor-air damper is closed when the indoor fan is not operating.

Refer to Service and Maintenance Manual for further details.

Note about this specification:

# GAS HEAT PACKAGED ROOFTOP

**HVAC Guide Specifications** 

Size Range: 17.5 to 25 Nominal Tons



Section Description

# 23 06 80 Schedules for Decentralized HVAC Equipment

23 06 80.13 Decentralized Unitary HVAC Equipment Schedule

23 06 80.13.A. Rooftop unit schedule

1. Schedule is per the project specification requirements.

### 23 07 16 HVAC Equipment Insulation

23 07 16.13 Decentralized, Rooftop Units:

- 23 07 16.13.A. Evaporator fan compartment:
  - 1. Interior cabinet surfaces shall be insulated with a minimum 1/2-in. thick, minimum 1 1/2 lb density, flexible fiberglass insulation bonded with a phenolic binder, neoprene coated on the air side.
  - 2. Insulation and adhesive shall meet NFPA 90A requirements for flame spread and smoke generation.
- 23 07 16.13.B. Gas heat compartment:
  - 1. Aluminum foil-faced fiberglass insulation shall be used.
  - 2. Insulation and adhesive shall meet NFPA 90A requirements for flame spread and smoke generation.

## 23 09 13 Instrumentation and Control Devices for HVAC

# 23 09 13.23 Sensors and Transmitters

23 09 13.23.A. Thermostats

- 1. Thermostat must
  - a. energize both "W" and "G" when calling for heat.
  - b. have capability to energize 2 different stages of cooling, and 2 different stages of heating.
  - c. include capability for occupancy scheduling.

# 23 09 33 Electric and Electronic Control System for HVAC

23 09 33.13 Decentralized, Rooftop Units:

23 09 33.13.A. General:

- 1. Shall be complete with self-contained low-voltage control circuit protected by a resettable circuit breaker on the 24-v transformer side. Transformer shall have 75VA capability.
- 2. Shall utilize color-coded wiring.
- 3. Shall include a central control terminal board to conveniently and safely provide connection points for vital control functions such as: smoke detectors, phase monitor, gas controller, economizer, thermostat, and low and high pressure switches.
- 4. The heat exchanger shall be controlled by an integrated gas controller (IGC) microprocessor. See heat exchanger section of this specification.
- 5. Unit shall include a minimum of one 8-pin screw terminal connection board for connection of control wiring.

### 23 09 33.23.B. Safeties:

- 1. Compressor over-temperature, over-current. High internal pressure differential.
- 2. Low-pressure switch.
  - a. Units shall have different sized connectors for the circuit 1 and circuit 2 low and high pressure switches. They shall physically prevent the cross-wiring of the safety switches between circuits 1 and 2.
  - b. Low pressure switch shall use different color wire than the high pressure switch. The purpose is to assist the installer and service technician to correctly wire and or troubleshoot the rooftop unit.

- 3. High-pressure switch.
  - a. Units shall have different sized connectors for the circuit 1 and circuit 2 low and high pressure switches. They shall physically prevent the cross-wiring of the safety switches between circuits 1 and 2.
  - b. High pressure switch shall use different color wire than the low pressure switch. The purpose is to assist the installer and service technician to correctly wire and or troubleshoot the rooftop unit.
- 4. Automatic reset, motor thermal overload protector.
- 5. Heating section shall be provided with the following minimum protections:
  - a. High-temperature limit switches.
  - b. Induced draft motor speed sensor.
  - c. Flame rollout switch.
  - d. Flame proving controls.

## 23 09 93 Sequence of Operations for HVAC Controls

- 23 09 93.13 Decentralized, Rooftop Units:
- 23 09 93.13 INSERT SEQUENCE OF OPERATION

### 23 40 13 Panel Air Filters

- 23 40 13.13 Decentralized, Rooftop Units:
- 23 40 13.13.A. Standard filter section
  - 1. Shall consist of factory-installed, low velocity, disposable 2-in. thick fiberglass filters of commercially available sizes.
  - 2. Unit shall use only one filter size. Multiple sizes are not acceptable.
  - 3. Filters shall be accessible through a dedicated, weather tight access panel.
  - 4. 4-in filter capabilities shall be capable with pre-engineered and approved filter track field installed accessory. This kit requires field furnished filters.

# 23 81 19 Self-Contained Air Conditioners

- 23 81 19.13 Medium-Capacity Self-Contained Air Conditioners (RGS210-313)
- 23 81 19.13.A. General
  - 1. Outdoor, rooftop mounted, electrically controlled, heating and cooling unit utilizing a fully hermetic scroll compressor(s) for cooling duty and gas combustion for heating duty.
  - 2. Factory assembled, single-piece heating and cooling rooftop unit. Contained within the unit enclosure shall be all factory wiring, piping, controls, and special features required prior to field start-up.
  - 3. Unit shall use environmentally sound, R-410A refrigerant.
  - 4. Unit shall be installed in accordance with the manufacturer's instructions.
  - 5. Unit must be selected and installed in compliance with local, state, and federal codes.

# 23 81 19.13.B. Quality Assurance

- 1. Unit meets ASHRAE 90.1 minimum efficiency requirements.
- 2. Units are Energy Star certified where sizes are required.
- 3. Unit shall be rated in accordance with AHRI Standard 340/360.
- 4. Unit shall be designed to conform to ASHRAE 15.
- 5. Unit shall be UL-tested and certified in accordance with ANSI Z21.47 Standards and UL-listed and certified under Canadian standards as a total package for safety requirements.
- 6. Insulation and adhesive shall meet NFPA 90A requirements for flame spread and smoke generation.
- 7. Unit casing shall be capable of withstanding 500-hour salt spray exposure per ASTM B117 (scribed specimen).
- 8. Unit casing shall be capable of withstanding Federal Test Method Standard No. 141 (Method 6061) 5000-hour salt spray.
- 9. Unit shall be designed in accordance with ISO 9001:2000, and shall be manufactured in a facility registered by ISO 9001:2000.
- 10. Roof curb shall be designed to conform to NRCA Standards.
- 11. Unit shall be subjected to a completely automated run test on the assembly line. The data for each unit will be stored at the factory, and must be available upon request.
- 12. Unit shall be designed in accordance with UL Standard 1995, including tested to withstand rain.
- 13. Unit shall be constructed to prevent intrusion of snow and tested to prevent snow intrusion into the control box up to 40 mph.
- 14. Unit shake tested to assurance level 1, ASTM D4169 to ensure shipping reliability.

- 15. High Efficient Motors listed shall meet section 313 of the Energy Independence and Security Act of 2007 (EISA 2007).
- 23 81 19.13.C. Delivery, Storage, and Handling
  - 1. Unit shall be stored and handled per manufacturer's recommendations.
  - 2. Lifted by crane requires either shipping top panel or spreader bars.
  - 3. Unit shall only be stored or positioned in the upright position.
- 23 81 19.13.E. Project Conditions
  - 1. As specified in the contract.
- 23 81 19.13.F. Operating Characteristics
  - 1. Unit shall be capable of starting and running at 115°F (46°C) ambient outdoor temperature, meeting maximum load criteria of AHRI Standard 340/360 at ± 10% voltage.
  - Compressor with standard controls shall be capable of operation down to 30°F (-1°C), ambient outdoor temperatures. Accessory winter start kit is necessary if mechanically cooling at ambient temperatures below 30°F (-1°C).
  - 3. Unit shall discharge supply air vertically or horizontally as shown on contract drawings.
  - 4. Unit shall be factory configured and ordered for vertical supply & return configurations.
  - 5. Unit shall be factory furnished for either vertical or horizontal configuration without the use of special conversion kits. No field conversion is possible. The supply air configuration determines the unit model number to be ordered.
- 23 81 19.13.G. Electrical Requirements
  - 1. Main power supply voltage, phase, and frequency must match those required by the manufacturer.
- 23 81 19.13.H. Unit Cabinet
  - 1. Unit cabinet shall be constructed of galvanized steel, and shall be bonderized and coated with a pre-painted baked enamel finish on all externally exposed surfaces.
  - Unit cabinet exterior paint shall be: film thickness, (dry) 0.003 inches minimum, gloss (per ASTM D523, 60°F / 16°C): 60, Hardness: H-2H Pencil hardness.
  - 3. Evaporator fan compartment interior cabinet insulation shall conform to AHRI Standard 340/360 minimum exterior sweat criteria. Interior surfaces shall be insulated with a minimum 1/2-in. thick, 1 lb density, flexible fiberglass insulation, neoprene coated on the air side. Aluminum foil-faced fiberglass insulation shall be used in the gas heat compartment.
  - 4. Base of unit shall have a minimum of four locations for thru-the-base gas and electrical connections standard. Both gas and electric connections shall be internal to the cabinet to protect from environmental issues.
  - 5. Base Rail
    - a. Unit shall have base rails on a minimum of 2 sides.
    - b. Holes shall be provided in the base rails for rigging shackles to facilitate maneuvering and overhead rigging.
    - c. Holes shall be provided in the base rail for moving the rooftop by fork truck.
    - d. Base rail shall be a minimum of 16 gauge thickness.
  - 6. Condensate pan and connections:
    - a. Shall be a sloped condensate drain pan made of a non-corrosive material.
    - b. Shall comply with ASHRAE Standard 62.
    - c. Shall use a 3/4-in -14 NPT drain connection, through the side of the drain pan. Connection shall be made per manufacturer's recommendations.
  - 7. Top panel:
    - a. Shall be a multi-piece top panel linked with water tight flanges and locking systems.
  - 8. Gas Connections:
    - a. All gas piping connecting to unit gas valve shall enter the unit cabinet at a single location on side of unit (horizontal plane).
    - b. Thru-the-base capability
      - (1.) Standard unit shall have a thru-the-base gas-line location using a raised, embossed portion of the unit basepan.
      - (2.) Optional, factory-approved, water-tight connection method must be used for thru-the-base gas connections.
      - (3.) No basepan penetration, other than those authorized by the manufacturer, is permitted.
  - 9. Electrical Connections
    - a. All unit power wiring shall enter unit cabinet at a single, factory-prepared, knockout location.
    - b. Thru-the-base capability.

- (1.) Standard unit shall have a thru-the-base electrical location(s) using a raised, embossed portion of the unit basepan.
- (2.) Optional, factory-approved, water-tight connection method must be used for thru-the-base electrical connections.
- (3.) No basepan penetration, other than those authorized by the manufacturer, is permitted.

10. Component access panels (standard)

- a. Cabinet panels shall be easily removable for servicing.
- b. Unit shall have one factory installed, tool-less, removable, filter access panel.
- c. Panels covering control box and filter shall have molded composite handles while the blower access door shall have an integrated flange for easy removal.
- d. Handles shall be UV modified, composite. They shall be permanently attached, and recessed into the panel.
- e. Screws on the vertical portion of all removable access panels shall engage into heat resistant, molded composite collars.
- f. Collars shall be removable and easily replaceable using manufacturer recommended parts.
- 23 81 19.13.I. Gas Heat
  - 1. General
    - a. Heat exchanger shall be an induced draft design. Positive pressure heat exchanger designs shall not be allowed.
    - b. Shall incorporate a direct-spark ignition system and redundant main gas valve.
    - c. Gas supply pressure at the inlet to the rooftop unit gas valve must match that required by the manufacturer.
  - 2. The heat exchanger shall be controlled by an integrated gas controller (IGC) microprocessor.
    - a. IGC board shall notify users of fault using an LED (light-emitting diode).
    - b. The LED shall be visible without removing the control box access panel.
    - c. IGC board shall contain algorithms that modify evaporator-fan operation to prevent future cycling on high temperature limit switch.
    - d. Unit shall be equipped with anti-cycle protection with one short cycle on unit flame rollout switch or 4 continuous short cycles on the high temperature limit switch. Fault indication shall be made using an LED.
  - 3. Standard Heat Exchanger construction
    - a. Heat exchanger shall be of the tubular-section type constructed of a minimum of 20-gauge steel coated with a nominal 1.2 mil aluminum-silicone alloy for corrosion resistance.
    - b. Burners shall be of the in-shot type constructed of aluminum-coated steel.
    - c. Burners shall incorporate orifices for rated heat output up to 2000 ft (610m) elevation. Additional accessory kits may be required for applications above 2000 ft (610m) elevation, depending on local gas supply conditions.
    - d. Each heat exchanger tube shall contain multiple dimples for increased heating effectiveness.
  - 4. Optional Stainless Steel Heat Exchanger construction
    - a. Use energy saving, direct-spark ignition system.
    - b. Use a redundant main gas valve.
    - c. Burners shall be of the in-shot type constructed of aluminum-coated steel.
    - d. All gas piping shall enter the unit cabinet at a single location on side of unit (horizontal plane).
    - e. The optional stainless steel heat exchanger shall be of the tubular-section type, constructed of a minimum of 20-gauge type 409 stainless steel.
    - f. Type 409 stainless steel shall be used in heat exchanger tubes and vestibule plate.
    - g. Complete stainless steel heat exchanger allows for greater application flexibility.
  - 5. Induced draft combustion motor and blower
    - a. Shall be a direct-drive, single inlet, forward-curved centrifugal type.
    - b. Shall be made from steel with a corrosion-resistant finish.
    - c. Shall have permanently lubricated sealed bearings.
    - d. Shall have inherent thermal overload protection.
    - e. Shall have an automatic reset feature.
- 23 81 19.13.J. Coils
  - 1. Standard Aluminum Fin Copper Tube Coils:
    - a. Standard evaporator and condenser coils shall have aluminum lanced plate fins mechanically bonded to seamless internally grooved copper tubes with all joints brazed.

- b. Evaporator coils shall be leak tested to 150 psig, pressure tested to 450 psig, and qualified to UL 1995 burst test at 1775 psig.
- c. Condenser coils shall be leak tested to 150 psig, pressure tested to 650 psig, and qualified to UL 1995 burst test at 1980 psig.
- 2. Optional Pre-coated aluminum-fin condenser coils:
- a. Shall have a durable epoxy-phenolic coating to provide protection in mildly corrosive coastal environments.
- b. Coating shall be applied to the aluminum fin stock prior to the fin stamping process to create an inert barrier between the aluminum fin and copper tube.
- c. Epoxy-phenolic barrier shall minimize galvanic action between dissimilar metals.
- 3. Optional Copper-fin evaporator and condenser coils:
  - a. Shall be constructed of copper fins mechanically bonded to copper tubes and copper tube sheets.
  - b. Galvanized steel tube sheets shall not be acceptable.
  - c. A polymer strip shall prevent coil assembly from contacting the sheet metal coil pan to minimize potential for galvanic corrosion between coil and pan.
- 4. Optional E-coated aluminum-fin evaporator and condenser coils:
  - a. Shall have a flexible epoxy polymer coating uniformly applied to all coil surface areas without material bridging between fins.
  - b. Coating process shall ensure complete coil encapsulation of tubes, fins and headers.
  - c. Color shall be high gloss black with gloss per ASTM D523-89.
  - d. Uniform dry film thickness from 0.8 to 1.2 mil on all surface areas including fin edges.
  - e. Superior hardness characteristics of 2H per ASTM D3363-92A and cross-hatch adhesion of 4B-5B per ASTM D3359-93.
  - f. Impact resistance shall be up to 160 in.-Ib (ASTM D2794-93).
  - g. Humidity and water immersion resistance shall be up to minimum 1000 and 250 hours respectively (ASTM D2247-92 and ASTM D870-92).
  - h. Corrosion durability shall be confirmed through testing to be no less than 1000 hours salt spray per ASTM B117-90.
- 5. Optional E-coated aluminum-fin, aluminum tube condenser coils:
  - a. Shall have a flexible epoxy polymer coating uniformly applied to all coil external surface areas without material bridging between fins or louvers.
  - b. Coating process shall ensure complete coil encapsulation, including all exposed fin edges.
  - c. E-coat thickness of 0.8 to 1.2 mil with top coat having a uniform dry film thickness from 1.0 to 2.0 mil on all external coil surface areas, including fin edges, shall be provided.
  - d. Shall have superior hardness characteristics of 2H per ASTM D3363-00 and cross-hatch adhesion of 4B-5B per ASTM D3359-02.
  - e. Shall have superior impact resistance with no cracking, chipping or peeling per NSF/ANSI 51-2002 Method 10.2.
- 23 81 19.13.K. Refrigerant Components
  - 1. Refrigerant circuit shall include the following control, safety, and maintenance features:
    - a. Fixed orifice metering system shall prevent mal-distribution of two-phase refrigerant by including multiple fixed orifice devices in each refrigeration circuit. Each orifice is to be optimized to the coil circuit it serves.
    - b. Refrigerant filter drier Solid core design.
    - c. Service gauge connections on suction and discharge lines.
    - d. Pressure gauge access through a specially designed access screen on the side of the unit.
  - 2. Compressors
    - a. Unit shall use fully hermetic, scroll compressor for each independent refrigeration circuit.
    - b. Models shall be available with 2 compressor/2 stage cooling and microchannel condenser coils.
    - c. Compressor motors shall be cooled by refrigerant gas passing through motor windings.
    - d. Compressors shall be internally protected from high discharge temperature conditions.
    - e. Compressors shall be protected from an over-temperature and over-amperage conditions by an internal, motor overload device.
    - f. Compressor shall be factory mounted on rubber grommets.
    - g. Compressor motors shall have internal line break thermal, current overload and high pressure differential protection.
    - h. Crankcase heaters shall not be required for normal operating range, unless provided by the factory.

# 23 81 19.13.L. Filter Section

- 1. Filters access is specified in the unit cabinet section of this specification.
- 2. Filters shall be held in place by a preformed, slide-out filter tray, facilitating easy removal and installation.
- 3. Shall consist of factory-installed, low velocity, throw-away 2-in. thick fiberglass filters.
- 4. Filters shall be standard, commercially available sizes.
- 5. Only one size filter per unit is allowed.
- 6. 4-in filter capability is possible with a field installed pre engineered slide out filter track accessory. 4-in filters are field furnished.
- 23 81 19.13.M. Evaporator Fan and Motor
  - 1. Evaporator fan motor:
    - a. Shall have inherent automatic-reset thermal overload protection or circuit breaker.
    - b. Shall have a maximum continuous bhp rating for continuous duty operation; no safety factors above that rating shall be required.
  - 2. Belt-driven Evaporator Fan:
    - a. Belt drive shall include an adjustable-pitch motor pulley and belt break protection system.
    - b. Shall use rigid pillow block bearing system with lubricant fittings at accessible bearing or lubrication line.
    - c. Blower fan shall be double-inlet type with forward-curved blades.
    - d. Shall be constructed from steel with a corrosion resistant finish and dynamically balanced.
- 23 81 19.13.N. Condenser Fans and Motors
  - 1. Condenser fan motors:
    - a. Shall be a totally enclosed motor.
    - b. Shall use permanently lubricated bearings.
    - c. Shall have inherent thermal overload protection with an automatic reset feature.
    - d. Shall use a shaft-down design.
  - 2. Condenser Fans:
    - a. Shall be a direct-driven propeller type fan.
    - b. Shall have aluminum blades riveted to corrosion-resistant steel spiders and shall be dynamically balanced.
- 23 81 19.13.O. Special Features Options and Accessories
  - 1. Integrated Economizers:
    - a. Integrated, gear-driven parallel modulating blade design type capable of simultaneous economizer and compressor operation.
    - b. Independent modules for vertical or horizontal return configurations shall be available. Vertical and horizontal return modules shall be available as a factory installed option.
    - c. Damper blades shall be galvanized steel with composite gears. Plastic or composite blades on intake or return shall not be acceptable.
    - d. Shall include all hardware and controls to provide free cooling with outdoor air when temperature and/or humidity are below setpoints.
    - e. Shall be equipped with gear driven dampers for both the outdoor ventilation air and the return air for positive air stream control.
    - f. Shall be equipped with low-leakage dampers, not to exceed 2% leakage at 1 in. wg pressure differential.
    - g. Shall be capable of introducing up to 100% outdoor air.
    - h. Shall be equipped with a barometric relief damper capable of relieving up to 100% return air.
    - i. Shall be designed to close damper(s) during loss-of-power situations with spring return built into motor.
    - j. Dry bulb outdoor-air temperature sensor shall be provided as standard. Outdoor air sensor setpoint shall be adjustable and shall range from 40 to 100°F / 4 to 38°C. Additional sensor options shall be available as accessories.
    - k. The economizer controller shall also provide control of an accessory power exhaust unit function. Factory set at 100%, with a range of 0% to 100%.
    - I. The economizer shall maintain minimum airflow into the building during occupied period and provide design ventilation rate for full occupancy. A remote potentiometer may be used to override the damper setpoint.
    - m. Dampers shall be completely closed when the unit is in the unoccupied mode.
    - n. Economizer controller shall accept a 2–10Vdc CO<sub>2</sub> sensor input for IAQ/DCV control. In this mode, dampers shall modulate the outdoor-air damper to provide ventilation based on the sensor input.
    - o. Compressor lockout sensor shall open at 35°F (2°C) and close closes at 50°F (10°C).
    - p. Actuator shall be direct coupled to economizer gear. No linkage arms or control rods shall be acceptable.

- q. Economizer controller shall provide indications when in free cooling mode, in the DCV mode, or the exhaust fan contact is closed.
- 2. Two-Position Motorized Damper
  - a. Damper shall be a Two-Position Damper. Damper travel shall be from the full closed position to the field adjustable %-open setpoint.
  - b. Damper shall include adjustable damper travel from 25% to 100% (full open).
  - c. Damper shall include single or dual blade, gear driven dampers and actuator motor.
  - d. Actuator shall be direct coupled to damper gear. No linkage arms or control rods shall be acceptable.
  - e. Damper will admit up to 100% outdoor air for applicable rooftop units.
  - f. Damper shall close upon indoor (evaporator) fan shutoff and/or loss of power.
  - g. The damper actuator shall plug into the rooftop unit's wiring harness plug. No hard wiring shall be required.
  - h. Outside air hood shall include aluminum water entrainment filter.
- 3. Manual damper
  - a. Manual damper package shall consist of damper, air inlet screen, and rain hood which can be preset to admit up to 25% outdoor air for year round ventilation.
- 4. Head Pressure Control Package
  - a. Controller shall control coil head pressure by condenser-fan speed modulation or condenser-fan cycling and wind baffles.
  - b. Shall consist of solid-state control and condenser-coil temperature sensor to maintain condensing temperature between 90°F (32°C) and 110°F (43°C)at outdoor ambient temperatures down to -20°F (-29°C).
- 5. Propane Conversion Kit
  - a. Package shall contain all the necessary hardware and instructions to convert a standard natural gas unit for use with liquefied propane. Kits shall be available for elevations from 0 up to 14,000 ft (4,276m).
- 6. Condenser Coil Hail Guard Assembly
  - a. Shall protect against damage from hail.
  - b. Shall be louvered style design.
- 7. Unit-Mounted, Non-Fused Disconnect Switch:
  - a. Switch shall be factory-installed, internally mounted.
  - b. National Electric Code (NEC) and UL approved non-fused switch shall provide unit power shutoff.
  - c. Shall be accessible from outside the unit.
  - d. Shall provide local shutdown and lockout capability.
- 8. Convenience Outlet:
  - e. Non-Powered convenience outlet.
    - (1.) Outlet shall be powered from a separate 115/120v power source.
    - (2.) A transformer shall not be included.
    - (3.) Outlet shall be factory-installed and internally mounted with easily accessible 115-v female receptacle.
    - (4.) Outlet shall include 15 amp GFI receptacles with independent fuse protection.
    - (5.) Outlet shall be accessible from outside the unit.
- 9. Flue Discharge Deflector:
  - a. Flue discharge deflector shall direct unit exhaust vertically instead of horizontally.
  - b. Deflector shall be defined as a "natural draft" device by the National Fuel and Gas (NFG) code.
- 10. Centrifugal Propeller Power Exhaust:
  - a. Power exhaust shall be used in conjunction with an integrated economizer.
  - b. Independent modules for vertical or horizontal return configurations shall be available.
  - c. Horizontal power exhaust is shall be mounted in return ductwork.
  - d. Power exhaust shall be controlled by economizer controller operation. Exhaust fans shall be energized when dampers open past the 0–100% adjustable setpoint on the economizer control.
- 11. Roof Curbs (Vertical):
  - a. Full perimeter roof curb with exhaust capability providing separate air streams for energy recovery from the exhaust air without supply air contamination.
  - b. Formed galvanized steel with wood nailer strip and shall be capable of supporting entire unit weight.
  - c. Permits installation and securing of ductwork to curb prior to mounting unit on the curb.
- 12. High Altitude Gas Conversion Kit:

- a. Package shall contain all the necessary hardware and instructions to convert a standard natural gas unit to operate from 3,000–10,000 ft (914 to 3048m) elevation and 10,001–14,000 ft (3049–4267m) elevation.
- 13. Outdoor Air Enthalpy Sensor:
  - a. The outdoor air enthalpy sensor shall be used to provide single enthalpy control. When used in conjunction with a return air enthalpy sensor, the unit will provide differential enthalpy control. The sensor allows the unit to determine if outside air is suitable for free cooling.
- 14. Return Air Enthalpy Sensor:
  - a. The return air enthalpy sensor shall be used in conjunction with an outdoor air enthalpy sensor to provide differential enthalpy control.
- 15. Indoor Air Quality (CO<sub>2</sub>) Sensor:
  - a. Shall be able to provide demand ventilation indoor air quality (IAQ) control.
  - b. The IAQ sensor shall be available in duct mount. The setpoint shall have adjustment capability.
- 16. Smoke detectors (Supply):
  - a. Shall be a Four-Wire Controller and Detector.
  - b. Shall be environmental compensated with differential sensing for reliable, stable, and drift-free sensitivity.
  - c. Shall use magnet-activated test/reset sensor switches.
  - d. Shall have tool-less connection terminal access.
  - e. Shall have a recessed momentary switch for testing and resetting the detector.
  - f. Controller shall include:
    - (1.) One set of normally open alarm initiation contacts for connection to an initiating device circuit on a fire alarm control panel.
    - (2.) Two Form-C auxiliary alarm relays for interface with rooftop unit or other equipment.
    - (3.) One Form-C supervision (trouble) relay to control the operation of the Trouble LED on a remote test/reset station.
    - (4.) Capable of direct connection to two individual detector modules.
    - (5.) Can be wired to up to 14 other duct smoke detectors for multiple fan shutdown applications
- 17. Winter start kit
  - a. Shall contain a bypass device around the low pressure switch.
  - b. Shall be required when mechanical cooling is required down to 25°F (-4°C).
  - c. Shall not be required to operate on an economizer when below an outdoor ambient of 40°F (4°C).
- 18. Time Guard
  - a. Shall prevent compressor short cycling by providing a 5-minute delay (±2 minutes) before restarting a compressor after shutdown for any reason.
  - b. One device shall be required per compressor.
- 19. Barometric Hood (Horizontal Economizer Applications)
  - a. Shall be required when a horizontal economizer and barometric relief are required. Barometric relief damper must be installed in the return air (horizontal) duct work. This hood provides weather protection.