

FIREX[®] Smoke Alarm

The professional choice in fire safety.

NEW ACCESSORIES

The NEW remote accessories are designed to be used with Firex duct smoke detectors to provide the most complete functionality ever available in such a device.

The remote accessory is available with either the single gang remote indicator/control (591 models), or with the addition of a single gang strobe assembly (592 models). Both versions are compatible with standard Decora style cover plates (choice of white, red or stainless steel). A strobe-only version (593 models) is available for retrofit upgrade of “controller only” installations.

The indicator/control assembly provides:

- Visual indication of detector Pilot, Trouble and Alarm Functions
- Selectable audible indication of Alarm, Trouble or both
- Buzzer Silence function, with silenced indication and “ringback” following condition correction
- Lamp/Buzzer test function
- Key-Operated detector Test and Reset functions
- Lever-operated “No-Tools” terminal block
- Port for plugging in the optional strobe assembly
- Black “DUCT SMOKE DETECTOR” decal included for front plate
- Blue “SMOKE”, red “FIRE” strobe lens decals included for both horizontal and vertical mounting

Strobe Connection

The strobe assembly provides visual indication of alarm conditions, and is connected to the indicator/control assembly via the provided polarized connector.

To install the strobe module, simply plug the provided connector onto the pins as indicated on the rear of the indicator/control module. Snap the strobe lens into the cover plate, and install cover plate following completion of remote module wiring.

NOTE: The strobe and audible buzzer features are not ADA compliant, and not intended for life safety notification or evacuation purposes (public mode). These functions are for duct smoke detector status indication only (private mode).

Duct Smoke Detector Remote Accessories


Universal Voltage Models Compatible with
230 VAC, 115 VAC, 24 VAC or 24 VDC operation

2650-760 Ionization • 2650-761 Photoelectric
2650-660 Ionization • 2650-661 Photoelectric
2650-560 Ionization • 2650-561 Photoelectric



Audible Buzzer Configuration

There are two jumpers located on the rear of the indicator/control assembly. To enable audible buzzer operation for Alarm or Trouble conditions, simply leave the jumpers in place. To disable either or both functions, remove the appropriate jumper(s).




Silence and Ringback Functions

On the occasion where an audible alarm or trouble condition needs to be silenced while the detector condition is inspected and remedied, the indicator/control module provides a silence function. The slide switch located on the front of the module is pushed DOWN to activate the silence function.

Upon correction of the notified condition, the silenced buzzer will resume sounding. The ringback feature serves as a reminder to reset the silence switch to the "normal", UP position.

Note that the strobe module, when installed, will not stop operating when the silence function is engaged.



Wiring

For appropriate duct detector wiring terminals, please refer to detector and remote accessory installation instructions.



Products

591 Series Remote Accessory Controllers

- 591W Remote Indicator/Control Assembly w/White Single Gang Cover Plate
- 591R Remote Indicator/Control Assembly w/Red Single Gang Cover Plate
- 591S Remote Indicator/Control Assembly w/Stainless Steel Single Gang Cover Plate

592 Series Remote Accessory Controllers with Strobe

- 592WC Remote Indicator/Control Assembly w/Strobe Assembly (Clear Lens); White Double Gang Cover Plate
- 592WO Remote Indicator/Control Assembly w/Strobe Assembly (Opaque Lens); White Double Gang Cover Plate
- 592RC Remote Indicator/Control Assembly w/Strobe Assembly (Clear Lens); Red Double Gang Cover Plate
- 592RO Remote Indicator/Control Assembly w/Strobe Assembly (Opaque Lens); Red Double Gang Cover Plate
- 592SC Remote Indicator/Control Assembly w/Strobe Assembly (Clear Lens); Stainless Steel Double Gang Cover Plate
- 592SO Remote Indicator/Control Assembly w/Strobe Assembly (Opaque Lens); Stainless Steel Double Gang Cover Plate

593 Series Remote Accessory Strobes (as an optional field upgrade kit for existing installed 591 Series Controllers)

- 593RC Strobe Assembly (Clear Lens); Red Double Gang Cover Plate
- 593RO Strobe Assembly (Opaque Lens); Red Double Gang Cover Plate
- 593SC Strobe Assembly (Clear Lens); Stainless Steel Double Gang Cover Plate
- 593SO Strobe Assembly (Opaque Lens); Stainless Steel Double Gang Cover Plate
- 593WC Strobe Assembly (Clear Lens); White Double Gang Cover Plate
- 593WO Strobe Assembly (Opaque Lens); White Double Gang Cover Plate

Power Requirements:	Standby	13mA
	Alarm LED	22mA
	Trouble with Buzzer	33mA
	Trouble Silenced	33mA
	Trouble without Buzzer	13mA
	Alarm with Buzzer	37mA
	Alarm Silenced with Buzzer	37mA
	Alarm with Buzzer and Strobe	154mA
	Alarm Silenced with Buzzer and Strobe	157mA
	Lamp Test with Buzzer	62mA
	Lamp Test with Buzzer Silenced	52mA

Sound Pressure: 60db @ 10 ft.

Dimensions:	Single Gang Plate:	4-1/2" (114.3 mm) H x 2-3/4" (69.85 mm) W
	Double Gang Plate:	4-1/2" (114.3 mm) H x 4-1/2" (114.33 mm) W

Wiring: 14-28 AWG. Solid or Stranded

Approvals: U.L. Listed for use with Firex duct smoke detectors including all 2650 Series duct smoke detectors
UL URRQ, URRQ7.S7425 / CSFM / MEA

Invensys®

Controls Americas
515 South Promenade Avenue
Corona California 92879-1736 USA
Cust. Svc. Telephone +1 800 951 5526
Cust. Svc. Facsimile +1 630 260 7299
iccacustomerservice@invensys.com

3505 Laird Road Unit #14
Mississauga Ontario L5L 5Y7 Canada
Cust. Svc. Telephone +1 800 387 7978
Cust. Svc. Facsimile +1 905 828 1265
iccacustomerservice@invensys.com

Technical Service
Telephone +1 800 445 8299
Facsimile +1 630 260 723
technicalservice@invensys.com



MEA ACCEPTED